

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

DODGE CITY NE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ABD

1. Location of well:	County Hodgeman	Fraction SE 1/4 NW 1/4 NE 1/4	Section number 22	Township number T 24 S	Range number R 25 E
2. Distance and direction from nearest town or city: 5 south, 8 west, 3 1/2 south, 1/2 west of Jetmore.			3. Owner of well: Melvin Nuss Lakin & Baker Great Bend, Ks. 67530		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			From	To	
			6. Bore hole dia. <u>26</u> in. Completion date <u>6-10-77</u> Well depth <u>150</u> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>steel</u> Height: Above <u>surface</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>151</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>.250</u>		
			10. Screen: Manufacturer's name <u>Johnson</u> Type <u>galv.</u> Dia. <u>16"</u> Slot/gauge <u> </u> Length <u>30</u> ft. Set between <u>110</u> ft. and <u>140</u> ft. Perf: <u>95-110</u> ft. and <u>140-150</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2" down</u>		
			11. Static water level: <u>79</u> ft. below land surface Date <u>4-30-77</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>95</u> ft. after <u>2</u> hrs. pumping <u>625</u> g.p.m. <u>99</u> ft. after <u>4</u> hrs. pumping <u>825</u> g.p.m. Estimated maximum yield <u>825</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
			14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter		
15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.					
16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds - US Pump</u> Model number <u>12JH10</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>140</u> ft. capacity <u>300</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>2535</u> <u>100 ft</u> <u>in of</u>				
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drilling Co. 208 Business name License No. Address <u>Box A Garden City, Ks.</u> Signed <u>[Signature]</u> Date <u>7-25-77</u> Authorized representative					

24 25 22 SE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

MELVIN NUSS
HODGEMAN COUNTY
4/7/77

Location: NE 22-24-35 200 east of pivot

Static Water Level- 76

Test #9

0	1	Top soil
1	4	Brown sandy clay
4	31	Light brown sandy clay mixed with rock
31	35	Fine to med. sand and gravel Loose
35	57	Brown sandy caly mixed with rock
57	71	Fine to med. sand and gravel small yellow rock
71	82	Brown clay
82	89	Fine to med. sand and gravel 10% clay
89	95	Fine to med. sand and gravel small yellow rock
95	128	Med. sand and gravel coarse yellow rock Loose
128	140	Med. sand and gravel coarse yellow rock hard
140	142	Yellow clay
142	145	Shale

T.D. 145
Screen 30
95 Plain
15 Perf
30 Screen
10 Perf