

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

DODGE CITY NE

ARF
NE NW NE

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Hodgeman	Fraction 1/4 NE 1/4 NW 1/4	Section number 22	Township number T 24 S	Range number R 25 E
2. Distance and direction from nearest town or city: 8 west-9 south-3/4 west of Jetmore Street address of well location if in city:			3. Owner of well: John Wilson R.R. or street: North Star Rt. City, state, zip code: Dodge City, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 5-5-78 Well depth 143 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	3	9. Casing: Material <u>metal</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 143 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 188		
Brown and coleche clay		3	35	10. Screen: Manufacturer's name W. A. Brown Type 17% Free-flo Dia. 16 Slot/gauze 1/8 Length 65 Set between 78 ft. and 143 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 3/8 CMA		
Med. sand and gravel		35	40	11. Static water level: <input type="checkbox"/> mo./day/yr. 80 ft. below land surface Date 3-31-78		
Coleche clay and sandrock		40	70	12. Pumping level below land surfaces: 130 ft. after 3 hrs. pumping 700 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 700 g.p.m.		
Fine to half med. sand		70	85	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Clay		85	86	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Half med. sand and fine gravel		86	91	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Hard rock layer		91	92	16. Nearest source of possible contamination: field ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Brown clay		92	104	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 10JMC HP 40 Volts <input type="checkbox"/> Length of drop pipe 130 ft. capacity 450 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Good med. to coarse sand and gravel		104	120	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Ks Signed Carl G. Tuttle Date 5-22-78 Authorized representative		
Hard rock layer		120	121			
Coarse sand and gravel		121	123			
Tan clay		121	127			
Coarse sand and gravel		127	132			
Hard rock and cemented gravel		132	134			
Yellow clay		134	143			
Gray shale		143	150			
<p>ROCK 134'</p> <p>80</p> <p>54' sat 16.1</p> <p>in Og</p> <p>(Use a second sheet if needed)</p>						
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	2538 1090					

T 24 R 25 E S 22 NE 1/4 1/4