

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

CAC

1. Location of well:		County Hodgeman	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 26	Township number T 24 S	Range number R 25 W
2. Distance and direction from nearest town or city: 11 north of Dodge City, 1 east, 3/4 south				3. Owner of well: Ray Charles R.R. or street: Jetmore, Ks. 67854 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 12-13-76 Well depth 97 ft.		
				7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: Domestic Public supply Industry <input checked="" type="checkbox"/> Irrigation Air conditioning Stock Lawn Oil field water Other		
				9. Casing: Material steel Height: Above or below Threaded Welded <input checked="" type="checkbox"/> Surface 12 in. RMP PVC Weight 36.87 lbs./ft. Dia. 16 in. to 98 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. .250		
				10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauze Length 20 ft. Set between 67 ft. and 87 ft. Perf: 87-97 ft. and ft. Gravel pack? yes Size range of material 1/2" down		
				11. Static water level: mo./day/yr. 67 ft. below land surface Date 10-19-76		
				12. Pumping level below land surfaces: 88 ft. after 3 hrs. pumping 350 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 350 g.p.m.		
				13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: Pitless adapter 12 inches above grade		
				15. Well grouted? yes With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Goulds - US Pump Model number 10 JMO HP 60 Volts Length of drop pipe 90 ft. capacity 300 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A, Garden City, Ks. Signed [Signature] Date 5-13-77 Authorized representative				

TRUCK 88  
67  
21' cat thick

in Og

(Use a second sheet if needed)

2531

TOIP

T 24 S 25 W  
 R 25 W  
 Sec 26  
 1/4 SW  
 1/4 NE  
 1/4 SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals*

**WINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 274-2269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

RAY CHARLES  
HODGEMAN COUNTY  
9-21-76

Well #1

Location: From NW corner of  $\frac{1}{4}$  section 500 Ft. south  
Static Water Level- 64'

Test #1

0	1	Top soil
1	7	Brown clay
7	41	Brown clay and white rock Hard
42	50	Fine to med. sand and gravel Loose
50	61	Fine to med. sand and gravel Loose small hard stks.
61	88	Fine to med. sand and gravel stks. of coarse gravel Loose
88	91	Brown and yellow clay Hard
91	95	Shale Hard