

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BAC

District C NW

1. Location of well:		County Hodgeman	Fraction SW NE SE 1/4 SW 1/4 NW 1/4	Section number 2	Township number 24	Range number 26
2. Distance and direction from nearest town or city: East of Kalvesta to first curve, take gravel road straight east to dead end, 1/2 south, 1/2 north west, 130' southwest		Owner of well: George Schlereth RFD 1		City, state, zip code: Garden City, Ks. 67846		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 2 1/2 in. Completion date 7-20-75 Well depth 136 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above 12 in. Threading <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36.87 in. RMP 16 PVC Weight 36.87 lbs./ft. Dia. 1 3/4 in. to 137 ft. depth Wall Thickness: inches or Dia. 1 3/4 in. to 137 ft. depth gage No. _____		
				10. Screens: Manufacturer's name: Johnson Division Type Galv. Dia. 16" Slot/gauze _____ Length 20' Set between 110 ft. and 130 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/2" down		
				11. Static water level: _____ mo./day/yr. 74 ft. below land surface Date 7-29-75		
				12. Pumping level below land surfaces: 91 ft. after 2 hrs. pumping 744 g.p.m. 105 ft. after 4 hrs. pumping 1245 g.p.m. Estimated maximum yield 1200 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name: Peerless - FMC Model number 5173 HP 100 Volts _____ Length of drop pipe 130 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name _____ License No. _____ Address Box 493 Garden City, Ks. Signed _____ Date _____ Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

BR 131 131
74
57' sat thick

TOPO 2578 in 08
131
2447 ✓

2 H 2 6 2
1/4 1/4 1/4 1/4

P.O. Box 493 GARDEN CITY, KANSAS 67846

George Schlereth
Hodgeman County
7-7-75

Location: East of Kalvesta to first curve, take gravel road straight east to dead end, $1\frac{1}{2}$ miles south, $\frac{1}{2}$ mile northwest
2-24-26 130 ft. southwest

Test #1 Pivot

0	1	Top soil
1	6	Brown clay
6	62	Brown clay & white rock (tight)
62	91	Fine to med. sand & gravel (loose)
91	95	Fine to med. sand & gravel, streaks of clay 15%
95	131	Fine to med. sand & gravel with brown rock (loose)
131	136	Brown & yellow clay with brown rock (hard)
136	140	Shale

Static Water Level: 70

T.D. 136'