


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>GRAY</b>	Fraction <b>SE 1/4 NW 1/4 SE 1/4</b>	Section number <b>18</b>	Township number <b>1 24 S R</b>	Range number <b>28 E/N</b>	
2. Distance and direction from nearest town or city: <b>1/4 mile north of Ingalls</b>	Sketch map: 	3. Owner of well: <b>Delmar Brady</b>	R.R. or street: <b>Ingalls, KS 67853</b>			
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. <b>26</b> in. Completion date <b>11-30-76</b> Well depth <b>230</b> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <b>steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <b>X</b> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>231</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			
			10. Screen: Manufacturer's name <b>Johnson Screen</b> Type <b>Galv.</b> Dia. <b>16"</b> 20' Slot/gauze <input type="checkbox"/> Length <b>216-226</b> ft. Set between <b>180-190</b> ft. and <b>216-226</b> ft. <b>Perf: 140-180</b> ft. and <b>190-216, 226-230</b> ft. Gravel pack? <b>yes</b> Size range of material <b>2-4</b> in. <b>down</b>			
			11. Static water level: mo./day/yr. <b>100</b> ft. below land surface Date <b>9-14-76</b>			
			12. Pumping level below land surfaces: <b>100</b> ft. after <b>1</b> hrs. pumping g.p.m. <b>100</b> ft. after <b>2</b> hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
			13. Water sample submitted: mo./day/yr. <b>Yes</b> <input type="checkbox"/> <b>No</b> <input type="checkbox"/> Date <input type="checkbox"/>			
			14. Well head completion: <input type="checkbox"/> Pitless adapter Inches above grade			
			15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.			
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <b>Yes</b> <input type="checkbox"/> <b>No</b> <input type="checkbox"/>			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:	(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling 208</b> Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address <b>Box A Garden City, KS</b> Signature <input type="checkbox"/> Date <b>2-24-77</b> Authorized representative <input type="checkbox"/>		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Casing was pulled - plugged					

Sent 4-5-77

*The Professionals* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DELMAR BRADY

GRAY COUNTY

9-14-76

Location: SE $\frac{1}{4}$  18-24-28 200 Ft. east of #3 Test

Static Water Level- 100'

Test #8

0	5	Top soil
5	22	Brown clay
22	51	Brown sandy clay
51	60	Fine to med. sand and gravel
60	84	Fine to med. sand and gravel Hard Pull Down
84	97	Fine to med. sand and gravel Loose
97	126	Fine to med. sand and gravel some clay stks. Loose
126	141	Brown clay and brown sandy clay
141	188	Fine to med. sand and gravel with white rock Loose
188	200	Fine to med. sand and gravel with white rock some clay stks. Loose
200	216	Fine to med. sand and gravel with white rock clay 20%
216	226	Fine to med. sand and gravel with white rock Loose
226	230	Shale

T.D. 230