


USE TYPEWRITER OR BALL
POINT PEN- FILL FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 29	Township number T 24 S R 28 E/W	Range number 28	
2. Distance and direction from nearest town or city: 7 N. & 1 1/2 E. of Ingalls Street address of well location if in city:				3. Owner of well: Clarence Penner R.R. or street: Ingalls, KS City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 36 in. Completion date 12-3-76 Well depth 250 ft.			
5. Type and color of material See attachment		From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
						9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32 lbs./ft. Dia. 16 in. to 250 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 188	
						10. Screen: Manufacturer's name Brown Type Louvered Dia. 16" Slot/gauze .125 Length 50' Set between 250 ft. and 240 ft. 230 ft. and 190 ft. Gravel pack? yes Size range of material 1/4 x 1/8	
						11. Static water level: 116 ft. below land surface Date 12-4-76 mo./day/yr.	
(Use a second sheet if needed)						12. Pumping level below land surfaces: 220 ft. after 640 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
						13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: None observed ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name _____ License No. _____ Address Box 639 Garden City, KS Signed E. L. Bethwell Date 12-29 Authorized representative	
						18. Elevation: Flat	
						19. Remarks:	
						Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

For #2 Well

LOCATION 75' E. of Test #6

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
BEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****