

1. LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number			
County: HARVEY		NW 1/4 SE 1/4 SE 1/4		8		T 24 S		R 3 W 4W			
Distance and direction from nearest town or city? 6 1/2 N. of Mt. Hope, Ks. Street Address of well if located within city?											
Mt. Hope, Ks., & 1/4 W., Mt. Hope, Ks.											
2. WATER WELL OWNER:		Delmer Blubaugh									
RR#, St. Address, Box #:		Burton, Ks.									
City, State, ZIP Code:		Board of Agriculture, Division of Water Resources Application Number:									
3. DEPTH OF COMPLETED WELL: 5 0 ft. Bore Hole Diameter: 3.0 in. to ft., and in. to ft.											
Well Water to be used as:											
1 Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well			
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)			
				7 Lawn and garden only		10 Observation well					
Well's static water level: 10 ft. below land surface measured on 9 month 15 day 8.0 year											
Pump Test Data: Well water was ft. after hours pumping gpm											
Est. Yield gpm: Well water was ft. after hours pumping gpm											
4. TYPE OF BLANK CASING USED:											
1 Steel		3 RMP (SR) Transit		5 Wrought iron		8 Concrete tile		Casing Joints: Glued Clamped X			
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		Welded			
				7 Fiberglass				Threaded			
Blank casing dia: 16 in. to 27 ft., Dia in. to ft., Dia in. to ft.											
Casing height above land surface: 12 in., weight 37 lbs./ft. Wall thickness or gauge No 3/4"											
TYPE OF SCREEN OR PERFORATION MATERIAL:											
1 Steel		3 Stainless steel		5 Fiberglass		7 PVC		10 Asbestos-cement Transit			
2 Brass		4 Galvanized steel Johnson		6 Concrete tile		8 RMP (SR)		11 Other (specify) Perf. Transit			
						9 ABS		12 None used (open hole)			
Screen or Perforation Openings Are:											
1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut Johnson		12 None (open hole)			
2 Louvered shutter		4 Key punched		6 Wire wrapped Johnson		9 Drilled holes					
				7 Torch cut		10 Other (specify)					
Screen-Perforation Dia: 16 in. to 50 ft., Dia in. to ft., Dia in. to ft.											
Screen-Perforated Intervals: From 27 ft. to 40 ft. Transit ft. From ft. to ft.											
From 40 ft. to 50 ft. Johnson ft. From ft. to ft.											
Gravel Pack Intervals: From 10 ft. to 50 ft. ft. From ft. to ft.											
From ft. to ft. From ft. to ft.											
5. GROUT MATERIAL:											
1 Neat cement		2 Cement grout		3 Bentonite		4 Other					
Grouted Intervals: From 40 ft. to 14 ft. ft. From ft. to ft.											
What is the nearest source of possible contamination? none											
1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage		14 Abandoned water well			
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		15 Oil well/Gas well			
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		16 Other (specify below)			
Direction from well: How many feet? Water Well Disinfected? Yes X No											
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample											
was submitted month day year: Pump installed? Yes No X											
If Yes: Pump Manufacturer's name Model No. HP Volts											
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.											
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other											
6. CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was											
completed on 9 month 15 day 80 year											
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236											
This Water Well Record was completed on 10 month 3 day 1980 year under the business											
name of Harp Well & Pump Service, Inc. by (signature) M. Arnold											
7. LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:											
FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
0		5		Clay							
5		10		Fine Sand							
10		50		Medium to Coarse Sand & Gravel							
ELEVATION:											
Depth(s) Groundwater Encountered 1. 10 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)											

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.