

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Harvey		Fraction NW 1/4 NE 1/4 1/4		Section number 17		Township number T 24 S		Range number R 3W E/W						
2. Distance and direction from nearest town or city: 6 1/2 miles North of Mt. Hope on the Burrton Rd, then 3/4 West, then 1/4 South. Burrton, KS					3. Owner of well: Milton Boyle R.R. or street: City, state, zip code: Burrton, Kansas									
4. Locate with "X" in section below: N S 1 Mile					Sketch map: N S 1 Mile					6. Bore hole dia. <u>11</u> in. Completion date <u>9-11-78</u> Well depth <u>65</u> ft.				
5. Type and color of material					From		To		7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary					
Sandy Topsoil					0		2		8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other					
Brown clay					2		7		9. Casing: Material <u>PVC</u> Height: Above or below Threaded ☐ Welded ☐ Surface <u>12</u> in. RMP ☐ PVC ☒ Weight <u>3.96</u> lbs./ft. Dia. <u>6</u> in. to <u>65</u> ft. depth Wall Thickness: inches or Dia. <u>6</u> in. to <u>65</u> ft. depth Gauge No. <u>316</u>					
Fine sand					7		20		10. Screen: Manufacturer's name <u>PVC NSF approved 200 PSI</u> Type <u>PVC 200 PSI</u> Dia. <u>6"</u> Slot/size <u>.06</u> Length <u>40'</u> Set between <u>25</u> ft. and <u>65</u> ft. <u>ft.</u> and <u>ft.</u> Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>					
Coarse sand					20		40		11. Static water level: <u>7</u> ft. below land surface Date <u>9-11-78</u> mo./day/yr.					
Light tan clay mixed with fine sand					40		60		12. Pumping level below land surfaces: <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>g.p.m.</u>					
Fine sand					60		65		13. Water sample submitted: <u>mo./day/yr.</u> <u>Yes</u> <u>No</u> Date <u>9-11-78</u>					
									14. Well head completion: <u>12</u> capped <u>Pitless adapter</u> <u>12</u> inches above grade					
									15. Well grouted? <u>yes</u> <u>1-2</u> fine sand mix With: <u>Neat cement</u> <u>Bentonite</u> ☒ Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.					
									16. Nearest source of possible contamination: <u>ft.</u> <u>Direction</u> <u>Type</u> <u>None</u> Well disinfected upon completion? ☒ Yes ☐ No					
									17. Pump: ☒ Not installed Manufacturer's name <u>Harp Well & Pump</u> Model number <u>236</u> HP <u>236</u> Volts <u>236</u> Length of drop pipe <u>ft.</u> capacity <u>g.p.m.</u> Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other					
18. Elevation: Flat ground No apparent source for contamination.					19. Remarks: Flat ground No apparent source for contamination.					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump <u>236</u> Business name <u>Wichita, Kansas</u> License No. <u>67209</u> Address <u>M. Arnold</u> Date <u>9-11-78</u> Signed <u>M. Arnold</u> Authorized representative				

$\frac{24}{T} - \frac{30}{R} = \frac{17}{Sec}$