

WATER WELL RECORD

Form WWC-5

Division of Water Resources App. No.

| | | | | |
|--|------------------------------|--|------------------------|---|
| 1 LOCATION OF WATER WELL: County: Finney | Fraction ¼ SE ¼ SW ¼ SW ¼ | Section Number 15 | Township No. T 24 S | Range Number R 31 <input type="checkbox"/> E <input checked="" type="checkbox"/> W |
| Street/Rural Address of Well Location; if unknown, distance & direction from nearest town or intersection: If at owner's address, check here <input checked="" type="checkbox"/> . | | Global Positioning System (GPS) information: Latitude: (in decimal degrees) Longitude: (in decimal degrees) Elevation: Datum: <input type="checkbox"/> WGS 84, <input type="checkbox"/> NAD 83, <input type="checkbox"/> NAD 27 Collection Method: <input type="checkbox"/> GPS unit (Make/Model:) <input type="checkbox"/> Digital Map/Photo, <input type="checkbox"/> Topographic Map, <input type="checkbox"/> Land Survey Est. Accuracy: <input type="checkbox"/> <3 m, <input type="checkbox"/> 3-5 m, <input type="checkbox"/> 5-15 m, <input type="checkbox"/> >15 m | | |
| 2 WATER WELL OWNER: Robert Dechant RR#, Street Address, Box #: 9855 E. Pole Line Rd. City, State, ZIP Code : Garden City, KS 67846 | | | | |

| | |
|--|---|
| 3 LOCATE WELL WITH AN "X" IN SECTION BOX: <div style="text-align: center;"> </div> | 4 DEPTH OF COMPLETED WELL 280 ft. Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft. WELL'S STATIC WATER LEVEL 197 ft. below land surface measured on mo/day/yr..... Pump test data: Well water was 217 ft. after 4 hours pumping 55 gpm EST. YIELD 100 gpm. Well water was ft. after hours pumping gpm Bore Hole Diameter 10 in. to 280 ft., and in. to ft. WELL WATER TO BE USED AS: <input type="checkbox"/> Public water supply <input type="checkbox"/> Geothermal <input type="checkbox"/> Injection well <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Feedlot <input type="checkbox"/> Oil field water supply <input type="checkbox"/> Dewatering <input type="checkbox"/> Other (Specify below) <input type="checkbox"/> Irrigation <input type="checkbox"/> Industrial <input type="checkbox"/> Domestic-lawn & garden <input type="checkbox"/> Monitoring well Was a chemical/bacteriological sample submitted to Department? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, mo/day/yr sample was submitted..... Water well disinfected? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
|--|---|

5 TYPE OF CASING USED: Steel PVC Other

CASING JOINTS: Glued Clamped Welded Threaded

Casing diameter 5 in. to 240 ft., Diameter in. to ft., Diameter in. to ft.
 Casing height above land surface 18 in., Weight 200 lbs./ft., Wall thickness or gauge No. SDR21

TYPE OF SCREEN OR PERFORATION MATERIAL:
 Steel Stainless Steel PVC Other (Specify)
 Brass Galvanized Steel None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:
 Continuous slot Mill slot Gauze wrapped Torch cut Drilled holes None (open hole)
 Louvered shutter Key punched Wire wrapped Saw cut Other (specify)

SCREEN-PERFORATED INTERVALS: From 240 ft. to 280 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.

GRAVEL PACK INTERVALS: From 25 ft. to 280 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.

6 GROUT MATERIAL: Neat cement Cement grout Bentonite Other

Grout Intervals: From 5 ft. to 25 ft., From ft. to ft., From ft. to ft.

What is the nearest source of possible contamination:
 Septic tank Lateral lines Pit privy Livestock pens Insecticide storage Other (specify below)
 Sewer lines Cesspool Sewage lagoon Fuel storage Abandoned water well
 Watertight sewer lines Seepage pit Feedyard Fertilizer storage Oil well/gas well

Direction from well South Distance from well 200

| FROM | TO | LITHOLOGIC LOG | FROM | TO | LITHO. LOG (cont.) or PLUGGING INTERVALS |
|------|-----|---|------|-----|--|
| 0 | 2 | Top Soil | 122 | 130 | Fine to Medium Sand |
| 2 | 26 | Brown Clay | 130 | 155 | Brown Clay |
| 26 | 45 | Brown Clay With Gypsum Streaks | 155 | 185 | Fine to Medium Sand Brown Clay Str. |
| 45 | 76 | Coarse Sand Small Gravel Few Small Cemented Streaks | 185 | 202 | Brown Clay with Small Sand Streaks |
| | | | 202 | 262 | Medium to Coarse Sand Small Gravel |
| 76 | 78 | Cemented Sand | | | Few Small Brown Clay Streaks |
| 78 | 89 | Medium to Coarse Sand | 262 | 278 | Coarse Sand Small Gravel White |
| 89 | 97 | Brown Clay | | | Broken Rock (Loose) |
| 97 | 115 | Medium To Coarse Sand | 278 | 280 | Yellow Soap Stone |
| 115 | 122 | Brown Sandy Clay | | | |

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo/day/year) 8-2-16 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 532 This Water Well Record was completed on (mo/day/year) 8-24-16 under the business name of Midwest Well & Pump Inc. by (signature)

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks and check the correct answers. Send three copies (white, blue, pink) to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one copy to WATER WELL OWNER and retain one for your records. Include fee of \$5.00 for each constructed well. Visit us at <http://www.kdheks.gov/waterwell/index.html>.