

WATER WELL RECORD (WWC-5)

Constructed

KOLAR DOC ID 1650776 WELL ID

Original Record Correction Change in Well Use

LOCATION OF WATER WELL

Latitude	37.990094	Longitude	-100.80957	Section	2	Township	24	Range	32	<input type="checkbox"/> E <input checked="" type="checkbox"/> W	Fraction	SW ¼ SW ¼ SW ¼
Datum	WGS84	Elevation	2881	County	Finney							

WATER WELL OWNER

Name	Shaun Hutcheson
Business	
Address	2760 N Farmland Garden City KS 67846
Well location	
<input checked="" type="checkbox"/> at owner's address	

WELL WATER USE

Domestic Livestock/Pasture

COMPLETION

Depth of completed well: 280 ft.
 Depth(s) groundwater encountered:
 (1) 161 ft.; (2) _____ ft.;
 (3) _____ ft.; (4) dry well

Static water level in well: 161 ft.
 measured below land surface on (mm/dd/yy): 06/24/2022
 measured above land surface on (mm/dd/yy): _____

Estimated yield: _____ gpm
 Water level was: _____ ft. after _____ hours pumping _____ gpm
 Pump installed? Yes No

Water well disinfected? Yes No
 Date disinfected (mm/dd/yy): _____

Aquifer, if known: _____

NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: _____
 Distance from well: _____ Direction from well: _____
 Source description: _____
 Source: _____
 Distance from well: _____ Direction from well: _____
 Source description: _____
 No potential source of contamination within 100 feet.

CONSTRUCTION

Borehole interval: from 0 to 280 ft. Borehole diameter: 10 in.
 from _____ to _____ ft. _____ in.

Casing height above land surface: 18 in.
 If casing height is less than 12 in. has a variance been approved?* Yes No
 *variance not required for monitoring or environmental remediation wells
 Casing type: ThermalPlastic

Blank casing interval: 0 ft. to 200 ft.
 Blank casing diameter: 5 in.
 Casing joints: Splines
 Weight: _____ lbs/ft.
 Wall thickness or gauge no.: SDR21

Blank casing interval: _____ ft. to _____ ft.
 Blank casing diameter: _____ in.
 Casing joints: _____
 Weight: _____ lbs/ft.
 Wall thickness or gauge no.: _____

Grout interval: 5 ft. to 40 ft.
 Grout material: Bentonite
 Grout interval: _____ ft. to _____ ft.
 Grout material: _____

Screen / perforation material: PVC
 Screen / perforation openings: Saw cut
 Screen / perforation intervals:
 From 200 ft. to 280 ft.
 Slot size .32 unit millimet
 From _____ ft. to _____ ft.
 Slot size _____ unit

Gravel pack intervals:
 Gravel pack not used: Gravel size _____ in
 From 0 ft. to 5 ft.
 Gravel pack not used: Gravel size _____ in
 From 40 ft. to 280 ft.

LITHOLOGIC LOG

FROM	TO	LITHOLOGY INTERVALS
Attach	Attach	Attached

COMMENTS

CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed reconstructed pursuant to the stated water well contractor's license and was completed on 06/24/2022. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on _____ under the business name of Nash Water Well Service, LLC, Kansas Water Well Contractor's License No. 846 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Trevor Nash

Send one copy to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.

555787

Form	WWC5.2 - Water Well Record
Doc ID	1650776
Well Owner	Shaun Hutcheson
Contractor	Nash Water Well Service, LLC

Lithology

0	3	topsoil
3	20	,Fine Medium Sand with tan & brown clay streaks
20	35	,Fine coarse sand with tan clay streaks
35	60	,Tan white clay caliche with fine medium sand
60	80	,Fine coarse sand with small to large gravel streaks & layers
80	100	,Fine coarse sand
100	120	,Fine medium sand
120	140	,Fine coarse sand
140	180	,Fine coarse sand with tan clay streaks & layers 80%
180	200	,Fine medium sand 95%
200	220	,Fine Medium Sand with tan clay 90%
220	260	,Fine Coarse sand 95%
260	280	,Fine sand tan clay 75%
280	284	,Tan Clay white rock caliche with fine sand 75%
284	300	,Tan yellow clay Blue Shale

RECEIVED
JUL 18 2022
BUREAU OF WATER

RECEIVED
SEP 15 2022
KS GEOLOGICAL SURVEY