


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Finney</b>	Township name	Fraction <b>SW, NE, NW</b>	Section number <b>25</b>	Town number <b>24S</b>	Range number <b>34W</b>
Distance and direction from nearest town or city: <b>2 1/2 Miles South and 3/4 miles west of Holcomb, Kansas</b>				3 Owner of well: <b>Loretta Mader R.R. Copeland, Kansas</b>		
Locate with "X" in section below: <div style="text-align: center;">  </div>				Sketch map: <b>Well located near TH 14-75 at center of NW 1/4, Sec. 25 T24S, R34W, Finney Co., Kansas</b>		
2				4 Well depth: <b>950-480</b> ft. Date of completion <b>10-11-75</b> Well diameter <b>28</b> in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Fine sand				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Fine to medium sand				7 Casing: Material <b>Stl.</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>188</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Fine to coarse sand fine to medium gravel				8 Screen: Manufacturer <b>Foster &amp; Brown</b> Type <b>mill slot, lower 16"</b> Slot/gauze <b>1/8"</b> Length <b>262</b> Set between <b>188</b> ft. and <b>950</b> ft. Fittings: <b>1.2 mm to 5.5 mm</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
Tan clay sand streaks				9 Static water level: <b>92</b> ft. below land surface Date <b>10-15-75</b>		
Fine to coarse sand fine to medium gravel clay streaks				10 Pumping level below land surfaces: <b>116</b> ft. after <b>1/2</b> hrs. pumping <b>1120</b> g.p.m. <b>128</b> ft. after <b>1</b> hrs. pumping <b>1471</b> g.p.m. Estimated maximum yield <b>2,000</b> g.p.m.		
Tan sandy clay				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Fine to coarse sand tight				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Tan clay				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite Depth: From <b>0</b> ft. to <b>10</b> ft.		
Fine to coarse sand fine to medium gravel				14 Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Black hard clay				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Layne &amp; Bowler</b> Model number <b>12K</b> HP <b>100</b> Volts <b>480</b> Length of drop pipe <b>160</b> ft. capacity <b>800</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Layne-Western Company, Inc.</b> Business name License No. Address <b>P.O. Box 686 W. Hwy.</b> Signed <b>[Signature]</b> Date <b>20 Nov 75</b> Authorized representative		
16 Remarks: elevation  Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5