

CORRECTION(S) TO WATER WELL RECORD (WWC-5)
(to rectify lacking or incorrect information)

Location listed as:

Section-Township-Range: 2-245-35W

Fraction ($\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$): SE NE NW

County: Finney

Location changed to:

2-245-34W

SE NE NW

Other changes: Initial statements: _____

Changed to: _____

Comments: _____

verification method: Written & legal descriptions, area road map,
and mapping tool on KGS website.


initials: DR date: 6/7/2012

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726
to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Finney	Fraction SE 1/4 NE 1/4 NW 1/4	Section number 2	Township number T 24 S	Range number R 35 W
2. Distance and direction from nearest town or city: 3 west of Holcomb on Hiway 50, 1/2 south, on south side of ditch.			3. Owner of well: George Potter R.R. or street: 610 Main St. City, state, zip code: Lafayette, Ind. 47902			
4. Locate with "X" in section below: 			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 4-14-77 Well depth 355 ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material steel Height: Above cas in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 356 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250	
					10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 1/8" Length 20 ft. Set between 320 ft. and 340 ft. Perf: 90-320 ft. and 340-355 ft. Gravel pack? yes Size range of material 2" down	
					11. Static water level: <input type="checkbox"/> mo./day/yr. 65 ft. below land surface Date 3-1-77	
					12. Pumping level below land surfaces: 113 ft. after 2 hrs. pumping 900 g.p.m. 145 ft. after 4 hrs. pumping 1500 g.p.m. Estimated maximum yield 1500 g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 14JMC HP 200 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A Garden City, Ks. Signed Michael DeLense Date 6-10-77 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

78-8269

Box A

GARDEN CITY, KANSAS 67846

GEORGE POTTER

BROWN BRAUN

FINNEY COUNTY

2/1/77

Location: N 2-24-35 1/4 west of curve north of Holcomb
on alley 50 ft south on south side of ditch
300 Ft. east of old well

Static Water Level- 32'

Test #1

0	4	Top soil
4	16	Brown clay
16	37	Fine to med. sand and gravel
37	52	Brown clay
52	94	Fine to med. sand and gravel
94	102	Brown clay
102	129	Fine to med. sand and gravel 10% clay
129	156	Brown clay
156	171	Fine to med. sand and gravel
171	201	Brown clay
201	217	Fine to med. sand and gravel
217	241	Brown clay
241	272	Fine to med. sand and gravel
272	286	Brown clay
286	352	Fine to med. sand and gravel
352	361	Brown and yellow clay
361	365	Shale

R.D. 355