


1 LOCATION OF WATER WELL: Fraction SW 1/4 NW 1/4 SW 1/4 Section Number 22 Township Number T 24 S Range Number R 35 E 11
 County: Kearny

Distance and direction from nearest town or city street address of well if located within city? Deerfield south across bridge, 1 mile South west on River Road, 1 South to the Southeast corner of section, 1790' North, 5230' West

2 WATER WELL OWNER: Carl Grauberger Trust
 RR#, St. Address, Box # : Box 284 Board of Agriculture, Division of Water Resource
 City, State, ZIP Code : Deerfield, KS 67838 Application Number: 10,437

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:  4 DEPTH OF COMPLETED WELL: 120 ft. ELEVATION:
 Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft.
 WELL'S STATIC WATER LEVEL .. 19 ft. below land surface measured on mo/day/yr June 10, 1996
 Pump test data: Well water was ft. after hours pumping gpm
 Est. Yield gpm: Well water was ft. after hours pumping gpm
 Bore Hole Diameter ... 30 ... in. to ... 120 ft., and in. to ft.
 WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well
 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
 Was a chemical/bacteriological sample submitted to Department? Yes.....No... X.....; If yes, mo/day/yr sample was submitted
 Water Well Disinfected? Yes No X

5 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded X
 2 PVC 4 ABS 7 Fiberglass Threaded
 Blank casing diameter 16 in. to 55 ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface 12 in., weight 42.05 lbs./ft. Wall thickness or gauge No. ... 250
 TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)
 SCREEN-PERFORATED INTERVALS: From 55 ft. to 115 ft., From 115 ft. to 120 ft.
 From ft. to ft., From ft. to ft.
 GRAVEL PACK INTERVALS: From 20 ft. to 120 ft., From ft. to ft.
 From ft. to ft., From ft. to ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grout Intervals: From 0 ft. to 20 ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
 13 Insecticide storage N/A

Direction from well? How many feet?

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
		SEE ATTACHED LOG			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was 1 constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) June 10, 1996 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208 This Water Well Record was completed on (mo/day/yr) June 19, 1996 under the business name of Minter-Wilson Drilling Company, Inc. by (signature) Kathy Olson



MINTER-WILSON DRILLING CO.

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

INCORPORATED

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Ron Grauberger
Kearny County
5/21/96

Location: SW $\frac{1}{4}$ 22-24-35 - From Deerfield Bridge - 2 $\frac{1}{4}$ miles south
on the east side of road
(140 ft. north & 15 ft. east of old well)

Static Water Level - 20'

Test #1

- 0' to 3' - Top soil
- 17 ~~01~~ 3' to 6' - Brown clay
- 17 ~~02~~ 6' to 46' - Fine to medium sand and gravel - loose
- 15 46' to 50' - Medium coarse gravel - loose
- 17 ~~15~~ 50' to 66' - Coarse gravel - loose
- 17 ~~15~~ 66' to 77' - Fine to medium sand and gravel - loose
- 17 77' to 95' - Medium coarse gravel - loose
- 17 95' to 104' - Fine to medium sand and gravel
- 04 ~~17~~ 104' to 110' - Brown sandy clay
- 17 110' to 117' - Fine to medium sand and gravel
- 117' to 125' - Brown sandy clay
- 125' to 154' - Brown gray clay
- 04 154' to 170' - Brown sandy clay

RECEIVED

JUN 24 1996

BUREAU OF WATER