

DRILLERS TEST LOG

CUSTOMER'S NAME: Kent Rixon **DATE:** 12/4/89
STREET ADDRESS: _____ **TEST #** 3 **E. LOG** Yes
CITY & STATE: St. John, Ks. 67576 **DRILLER** Wildeman
COUNTY Kearny **QUARTER** NE **SECTION** 29 **TOWNSHIP** 24 **RANGE** 35

LOCATION 291' East of the old well on the South side of Irrigation Ditch.

WELL LOCATION

Z	FOOTAGE			DESCRIPTION OF STRATA	STATIC WATER LEVEL: _____
	From	Pay	TO		Proposed Well Depth:
	0		3	Top soil.	
	3		58	Sand, gravel & cobblestones (very loose) used water.	
	58		94	Brown sandy clay, Caliche & few sand streaks.	
	94		110	Blue clay & very fine sand.	
	110		141	Blue clay & sand.	
	141		149	Sand fine to medium, few coarse & few clay streaks. (Very loose in places).	
	149		160	Brown sandy clay & few clay streaks.	
60	160	15	175	Sand fine to medium coarse. Small gravel, few clay streaks (loose) used water.	
65	175	25	200	Sand fine to medium coarse. Small gravel (loose).	
	200		207	Brown sandy clay.	
65	207	13	220	Sand fine to medium coarse. Small gravel (very loose). Used water.	
	220		223	Brown sandy clay.	
60	223	17	240	Sand fine to medium (very loose) used water.	
75	240	17	257	Sand fine to medium coarse. Small gravel (very loose) used lots of water & white rock.	
	257		260	Brown clay.	
70	260	25	285	Sand fine to medium coarse. Small gravel & brown & white rock (very loose) used lots of water.	
50	285	33	318	Sand fine to medium, few clay streaks (loose).	
20	318	22	330	Sandstone & soapstone.	
	330		340	Soapstone & shale.	
				Total depth = 333'	
				5 - sacks of Quick Gel	
				1/4 - bag of Bran	
				1 - sack of hole plug	
				1 - nerma plug	
				Jed "A"	
				Move hole over 4' North.	
				Set up East	
				Pit on South	

GARDEN CITY, KS 67846
 3795 West Jones Ave.

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

316-277-2389

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * * STOCK WELLS