

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction SE 1/4 SW 1/4 SW 1/4	Section number 30	Township number T 24 S	Range number R 35 E
2. Distance and direction from nearest town or city: Approx. 3 miles E. of Lakin, Kansas Street address of well location if in city:			3. Owner of well: Davis Williams R.R. or street: Box 71 City, state, zip code: Lakin, Kansas 67860		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date <u>2-2-76</u> Well depth <u>105</u> ft.	
		<p>1320; E of the SW corner of SW 1/4, Sec. 30, 24-35, Kearny</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material <u>STL</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>37</u> lbs./ft. Dia. <u>16</u> in. to <u>45</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>219</u>	
				10. Screen: Manufacturer's name <u>Cook and Doerr</u> <u>Louvered & Wire wrapped</u> Dia. <u>16"</u> Slot/gauze <u>1/8"</u> Length <u>60'</u> Set between <u>45</u> ft. and <u>105</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>2.5-9.5</u>	
				11. Static water level: <u>15</u> ft. below land surface Date <u>6-12-75</u> mo./day/yr.	
				12. Pumping level below land surfaces: <u>31</u> ft. after <u>1</u> hrs. pumping <u>1585</u> g.p.m. <u>45</u> ft. after <u>1</u> hrs. pumping <u>2620</u> g.p.m. Estimated maximum yield <u>3000</u> g.p.m.	
				13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>	
				14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade	
				15. Well grouted? <u>Yes</u> With: <u> </u> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination <u>Unk</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <u>Wellline</u> <input type="checkbox"/> Not installed Manufacturer's name <u>Layne & Bowler</u> Model number <u>12TL</u> HP <u>25</u> Volts <u>230</u> Length of drop pipe <u>50</u> ft. capacity <u>1600</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Layne Western Co., Inc.</u> <u>150</u> Business name License No. Address <u>P O Box 686 G. C. Ks.</u> Signed <u>[Signature]</u> Date <u>10 May 76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T
R
S
D
M
Sec
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

