

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Florence
WALTER FLETCHER
Kearny County
April 7, 1982

Location: For Walter's mother at home place

Static Water Level - 30

Test #

0	1	Top Soil
1	8	Brown Clay
8	24	Medium to Coarse Gravel Loose
24	86	Brown Clay
86	110	Blue Clay
110	140	Brown Clay 30% Gravel
140	157	Brown Clay
157	176	Fine to Medium Sand & Gravel 10% Clay (Loose)
176	180	Brown Clay 35% Gravel (Tight)
180	192	Brown Clay
192	200	Fine to Medium Sand & Gravel 10% Clay (Loose)
200	224	Fine to Medium Sand & Gravel 35% Clay (Tight) (Hard Streaks)
224	230	Fine Sand 10% Clay (Loose)
230	237	Fine to Medium Sand & Gravel 10% Clay (Loose)
237	260	Brown Sandy Clay 30% Gravel
260	273	Fine to Medium Sand & Fine Gravel 40% Clay
273	284	Brown & Yellow Clay (Hard)

Lost Circulation 280'

Dug Well 200'

Set 6 5/8 Pipe 201'
30' Perf