

CORRECTION(S) TO WATER WELL RECORD (WWC-5)

(to rectify lacking or incorrect information)

County: Kearny

Location listed as:

Location changed to:

Section-Township-Range: 28-245-36 W

28-245-36 W

Fraction ($\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$): None Given

SW NW NE

Other changes: Initial statements: _____

Changed to: _____

Comments: _____


verification method: written & legal descriptions, position on plat map,
and mapping tool on KGS website.

initials: DRd date: 4/12/2006

1 LOCATION OF WATER WELL: County: **Kearny** Fraction: $\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$ Section Number: **28** Township Number: T **24** S Range Number: R **36** EW

Distance and direction from nearest town or city street address of well if located within city?
NW corner of Lakin- $\frac{1}{2}$ W & $\frac{1}{2}$ S Lot 9 Country Heights 2nd Sub Division

2 WATER WELL OWNER: **Edward Wiatt**
 RR#, St. Address, Box # : **P.O. Box X** Board of Agriculture, Division of Water Resources
 City, State, ZIP Code : **Lakin, Kansas** Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:


4 DEPTH OF COMPLETED WELL: **190** ft. ELEVATION:
 Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft.
 WELL'S STATIC WATER LEVEL: **73** ft. below land surface measured on mo/day/yr **9-9-04**
 Pump test data: Well water was ft. after hours pumping gpm
 Est. Yield gpm: Well water was ft. after hours pumping gpm
 WELL WATER TO BE USED AS:
 Domestic Feedlot Oil field water supply Dewatering Other (Specify below)
 Irrigation Industrial Domestic (lawn & garden) Air conditioning Injection well Monitoring well
 Was a chemical/bacteriological sample submitted to Department? Yes No ; If yes, mo/day/yr sample was submitted
 Water Well Disinfected? Yes No

5 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing diameter in. to **130** ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface **12** in., weight **2.81** lbs./ft. Wall thickness or gauge No. **SDR21**
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless Steel 5 Fiberglass 7 PVC 10 Asbestos-Cement
 2 Brass 4 Galvanized Steel 6 Concrete tile 8 RMP (SR) 11 Other (Specify)
 12 None used (open hole)
 SCREEN OR PERFORATION OPENINGS ARE:
 1 Continuous slot 3 Mill slot 5 Guazed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)
 SCREEN-PERFORATED INTERVALS: From **130** ft. to **190** ft., From ft. to ft.
 GRAVEL PACK INTERVALS: From **26** ft. to **60** ft., From **115** ft. to **190** ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grout Intervals: From **6** ft. to **26** ft., From **60** ft. to **115** ft., From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Lateral lines 7 Pit privy 14 Abandoned water well
 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well
 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below)
 13 Insecticide storage
 Direction from well? **Southeast** How many feet? **15**

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
		See Attached Log			
					RECEIVED OCT 08 2004 BUREAU OF WATER

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was constructed, reconstructed, or plugged under my jurisdiction and was completed on (mo/day/year) **9-10-04** and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's Licence No **208** This Water Well Record was completed on (mo/day/yr) **9/20/04** under the business name of **Minter Wilson Drilling Co. Inc.** by (signature) *Nora Keller*

*The
Professionals*

MINTER-WILSON DRILLING CO.

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

INCORPORATED

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Ed Wiatt
Kearney County
9/3/04

Location: Country Heights - From Lakin- $\frac{1}{2}$ mile west, $\frac{1}{2}$ mile south
about 400 Ft. northeast

Static Water Level -

Test # 1

0' to 2' - Top Soil
2' to 18'- Brown Clay
18' to 24'- Fine to medium sand and gravel
24' to 28'- Brown sandy clay
28' to 60'- Fine to medium sand
60' to 71'- Brown sandy clay
71' to 87'- Brown sandy clay-small gravel streak
87' to 132'-Brown clay
132' to 152'-Fine to medium sand and gravel
152' to 160'-Fine to medium sand-tight
160' to 178'-Brown clay
178' to 184'-Cemented sand-hard
184' to 188'-Yellow clay

RECEIVED

OCT 08 2004

BUREAU OF WATER