


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 14	Township number T 24 S R 36 E W 3	Range number
2. Distance and direction from nearest town or city: 1 N & 1/2 E of Lakin Street address of well location if in city:			3. Owner of well: Garden City Co. R.R. or street: P.O. Box 597 City, state, zip code: Garden City, KS 67846		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material See attachment			From	To	6. Bore hole dia. 26 in. Completion date 2-7-77 Well depth 340 ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 340 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219
					10. Screen: Manufacturer's name Brown Type Louvered Dia. 16" Slot/gauze .080 Length 100' Set between 340 ft. and 240 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4 x 1/8
					11. Static water level: <input type="checkbox"/> mo./day/yr. 55' ft. below land surface Date <input type="checkbox"/>
					12. Pumping level below land surfaces: 116 ft. after <input type="checkbox"/> hrs. pumping 1451 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: None observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Johnston Model number 14cc HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 205 ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name Box 639, Garden City, KS License No. <input type="checkbox"/> Address A.A. Raubert Date 3-3-77 Signed A.A. Raubert Authorized representative		

2436014 SEE ATTACHMENT

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME The Garden City Company DATE 2-2-77
 STREET ADDRESS P. O. Box 597 TEST # 1 A E. LOG
 CITY & STATE Garden City, Kansas DRILLER Martinez
 COUNTY Kearny QUARTER SW SECTION 14 TOWNSHIP 24 RANGE 36
 LOCATION 400 Ft. West of Test # 1

%	FOOTAGE		DESCRIPTION OF STRATA	WELL LOCATION	
	From	Pay To		Static Water Level _____	Proposed Well Depth _____
	0	3	Top soil		
	3	20	Brown clay		
	20	49	Sand fine to med. coarse, few clay st.		
	49	120	Blue clay, sticky		
	120	125	Blue sand		
	125	160	Blue clay sticky		
	160	201	Brown clay		
45	201	05 206	Sand fine to med. coarse. Loose, Used water.		
	206	210	Brown clay		
40	210	15 235	Sand fine to med. Loose. Used water. Few clay st.		
	235	240	Brown sandy clay		
40	240	05 245	Sand fine to med. Loose. Used water. Few white rock st.		
60	245	06 251	Sand fine to med. coarse, small gravel. Loose. Used water. Few white rock st.		
	251	260	Brown clay		
75	260	25 285	Sand fine to med. coarse, small to med. gravel. Loose. Used water, few brown and white rock st.		
	285	286	Brown clay		
65	286	14 300	Sand fine to med. coarse, small and few med. gravel. Loose Used water, few white rock st.		
75	300	19 319	Sand fine to med. coarse, small to med. gravel. Loose. Used water, few white and brown rock st.		
75	319	321	Brown clay		
55	321	09 330	Sand fine to med. coarse, few, small gravel. Loose. Used water.		
	330	339	Yellow clay		
	339	345	Silt, hard.		
TOTAL DEPTH OF WELL 340 Ft.					
Set rig up to the West					
Pit on the North					