

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

CBC

WATER WELL RECORD
KSA 82a-1201-1215


Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kearny	Fraction SW 1/4 NW 1/4 SW 1/4	Section number 4	Township number T 24 S R 37	Range number 37
2. Distance and direction from nearest town or city: Street address of well location if in city:		7 west, 3 north, 100 ft. east of Lakin.		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date <u>5-13-77</u> Well depth <u>297</u> ft.		
		<p>7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>298</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>250</u></p>		<p>10. Screen: Manufacturer's name <u>Johnson</u> Type <u>galv.</u> Dia. <u>16"</u> Slot/gauge <u> </u> Length <u>20</u> ft. Set between <u>270</u> ft. and <u>290</u> ft. Perf: <u>250-270</u> ft. and <u>290-297</u> ft. Gravel pack? <u>yes</u> Size range of material <u>2" down</u></p> <p>11. Static water level: <u>232</u> ft. below land surface Date <u>3-23-77</u> mo./day/yr.</p> <p>12. Pumping level below land surfaces: <u>289</u> ft. after <u>3</u> hrs. pumping <u>400</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>400</u> g.p.m.</p> <p>13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u></p> <p>14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade</p> <p>15. Well grouted? <u> </u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.</p> <p>16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds - US Pump</u> Model number <u>10JIC</u> HP <u>80</u> Volts <u> </u> Length of drop pipe <u>280</u> ft. capacity <u>400</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p>		
5. Type and color of material		From	To			
BROOK 292'						
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. <u> </u> Address <u>Box A Garden City, Ks.</u> Signed <u>Andrew A. Jensen</u> Date <u>9-30-77</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 24 S R 37 E Sec 4 SW 1/4 NW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5



MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON RHA
TARRANT COUNTY
7-28-76

Location: Sec 14-24-37 south west corner of quarter 300 ft. out
Static Water Level- 243'

Test #3

0	4	Top soil
4	22	Brown clay and white rock
22	95	Fine to med. sand and gravel
95	121	Brown clay
121	275	Fine to med. sand and gravel
275	292	Fine to med. sand and gravel white rock light
292	297	Yellow clay
297	305	Shale