

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KEARNY	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 12	Township number T 24 S	Range number R 37 E
2. Distance and direction from nearest town or city: 3 west 3 north 1/8 west 1/4 south Lakin Street address of well location if in city:				3. Owner of well: Elton Beymer R.R. or street: Lakin, Ks. 67860 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 26 in. Completion date 5-21-76 Well depth 312 ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material <u>steel</u> Height: <u>Above</u> <u>MSL</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>312</u> ft. depth Wall thickness: <u>inches</u> or Dia. <u>16</u> in. to <u>312</u> ft. depth gage No. <u>219 MNC</u>		
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>277-297</u> ft. and <u>ft.</u> Perf. <u>230-277</u> ft. and <u>297-312</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2" Down</u>		
				11. Static water level: <u>220</u> ft. below land surface Date <u>2-2-76</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u>290</u> ft. after <u>3</u> hrs. pumping <u>700</u> g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>700</u> g.p.m.		
				13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u> <input type="checkbox"/> Date <u>mo./day/yr.</u>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>N/A</u> ft. <u>Direction</u> <u>Type</u> <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>_____</u> Model number <u>_____</u> HP <u>_____</u> Volts <u>_____</u> Length of drop pipe <u>_____</u> ft. capacity <u>_____</u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Wilson Drilling 208</u> Business name License No. <u>_____</u> Address <u>P.O. Box A Garden City, Ks.</u> Signed <u>Elton Beymer</u> Date <u>9-22-76</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

24 37 E 22 N/2 NE NE
 T R Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

WILSON DRILLING

Phone 275-2269 P.O. Box 495 BARNHART CITY, KANSAS 67002

WILSON DRILLING
BARNHART CITY, KANSAS
1957-78

Location 89 1/2 Miles West, 1 1/2 Miles North
of Barnhart, 10 Feet South of Main Street
Static Water Level 120'

Test #1

0	2	Top Soil
2	41	Brown Sand & Clay, Brown Rock, Hard
41	67	Fine To Med. Sand & Gravel, Hard
67	74	Brown Sandy Clay
74	82	Fine To Med. Sand & Gravel
82	86	Brown Sandy Clay
86	103	Fine To Med. Sand & Gravel
103	126	Light Brown Sandy Clay
126	148	Fine To Med. Sand & Gravel, Tight
148	157	Brown Sandy Clay
157	185	Fine To Med. Sand & Gravel, Tight
185	200	Fine To Med. Sand & Gravel Mixed White Rock
200	216	Brown Sandy Clay
216	242	Fine To Med. Sand & Gravel
242	244	Brown Sandy Clay
244	254	Fine To Med. Sand & Gravel, Loose
254	260	Brown Sandy Clay
260	265	Fine To Med. Sand & Gravel
265	272	Brown Sand, Clay, Gravel Streak
272	281	Fine To Med. Sand & Gravel, Tight
281	290	Yellow Clay, Brown Rock, Hard
290	320	Yellow, Red Clay, Brown Rock, Hard