

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

David Bilderback
Kearny County
2/4/95

Location: NE $\frac{1}{4}$ 25-24-37
From Lakin - 3 Miles West, 3/10ths of a
Mile South & 100 Ft. West

Static Water Level - 118'

Test #2

0' to 1' - Top soil
1' to 6' - Brown clay
6' to 15' - Fine to medium sand and gravel
15' to 39' - Brown sandy clay
39' to 51' - Fine to medium sand - loose
51' to 63' - Fine to medium sand cemented sand
stone mixed - tight
63' to 65' - Brown clay
65' to 77' - Yellow gray clay
77' to 99' - Fine to medium sand and gravel - loose
99' to 107' - Brown yellow rock - hard pull down
107' to 110' - Blue yellow clay mixed
110' to 121' - Sand stone
121' to 130' - Gray yellow clay
130' to 142' - Shale
142' to 146' - Gray yellow clay - 10% sand stone
- tight
146' to 148' - Sand stone - Dakota
148' to 159' - Yellow gray clay - small sand stone
streak - hard pull down
159' to 216' - Sand stone - hard pull down - Dakota
216' to 309' - Shale - hard pull down
309' to 317' - Streak yellow clay sand stone mixed
317' to 324' - Shale - hard pull down
324' to 328' - Sand Stone
328' to 395' - Shale - hard pull down

106 - Lost Circulation