

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Hamilton	Fraction Se 1/4 NE 1/4 SE 1/4	Section number 25	Township number T 24 S R 39 E 10	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:		
NW corner of Kendall			Earnest Weight Kendall, Ks. 67857		
4. Locate with "X" in section below: house Sketch map:			6. Bore hole dia. 7 7/8 in. Completion date _____ Well depth 102 ft. 5/12/76		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dig <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material RMP Height Above or below Threaded _____ Welded glue Surface 2 1/4 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 102 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0320		
			10. Screen: Manufacturer's name Jess & Lowell Type Styrene Dia. 5" Slot/gauze 1/16 Length 20' Set between 82 ft. and 102 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/16		
fine to med. sand			11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 3/1/76		
coarse sand & gravel			12. Pumping level below land surfaces: 50 ft. after 2 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.		
shale			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
fine sandstone			14. Well head completion: _____ Pitless adapter 2 1/4 inches above grade		
sandstone			15. Well grouted? yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.		
sandstone			16. Nearest source of possible contamination: ft. 201 Direction NW Type House Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply, Inc. Business name _____ License No. B1136 Address 402 N 3rd Signed Arthur B. Ruckman Date 6-2-76 Authorized representative		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 24 S 39 E 25 SE NE SE
R
Sec 1/4 1/4 1/4