

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CBB

1. Location of well:		County Hamilton	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 36	Township number T 24 S R 39	Range number E 10
2. Distance and direction from nearest town or city: Kendall Street address of well location if in city:			3. Owner of well: Roger Ramsey R.R. or street: Imperial Route City, state, zip code: Garden City, Kansas 67846			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 16 Feb. 76 Well depth 46 ft.		
		<p>SW corner of the NW 1/4 Sec. 36, T24S, R39W, Hamilton, Kansas.</p>		7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top soil				0	2	9. Casing: Material Stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 6 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
Coarse sand and gravel				2	21	10. Screen: Manufacturer's name Doerr
Gravel and boulders				21	50	Type Louver Dia. 16" Slot/gauze 1/8" Length 40 Set between 6 ft. and 46 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 6mm
Black shale				50	60	11. Static water level: <input type="checkbox"/> mo./day/yr. 6 ft. below land surface Date 4-30-75
BROCK 50'						12. Pumping level below land surfaces: 16 ft. after 1 hrs. pumping 963 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1000 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 5 ft.
						16. Nearest source of possible contamination: Unk ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 12KL HP 60 Volts <input type="checkbox"/> Length of drop pipe 30 ft. capacity 700 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 150 Business name License No. Address Garden City, Kansas Signed [Signature] Date 26 May 76 Authorized representative
18. Elevation:	19. Remarks: 3135 (TOPO)					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

2439E36
 T
 R
 Sec
 1/4
 1/4
 NW
 NE
 SW
 SE