

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HAMILTON	Fraction NE SE 1/4 SE 1/4 SE 1/4	Section number 5	Township number 24	Range number 40 E/W
<input checked="" type="checkbox"/> Distance and direction from nearest town or city: 1 E @ 1/4 N	3. Owner of well: Ted Burnett		R.R. or street: _____		
Street address of well location if in city: Syracuse		City, state, zip code: Syracuse Ks 67878			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 2 1/4 in. Completion date 8-18-79 Well depth 412 ft.	
		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		9. Casing: Manitowish Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 2 in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 250		10. Screen: Manufacturer's name Jess Lowell Type Sawed Dia. 5 Slot/gauze 3/32 X length 20 Set between 260 ft. and 280 ft. 350 ft. and 400 ft. Gravel pack? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No range of material CMH	
5. Type and color of material		From	To	11. Static water level: _____ mo./day/yr. 215 ft. below land surface Date 8-20-79	
Overburden - Broken lime		0	15	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.	
Blue Shale		15	215	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Dakota Sand		215	280	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
Shale		280	344	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.	
Dakota Sand		344	412	16. Nearest source of possible contamination: ft. 150 Direction SW Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name Goulds Model number 2SE1 HP 5 Volts 230 Length of drop pipe 340 ft. capacity 30 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Fulton Drilling 300 Business name _____ License No. _____ Address Syracuse, Ks Signed [Signature] Date 8-30-79 Authorized representative	
18. Elevation:		19. Remarks: 15' 8" surface set & cemented			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 24
 R 40
 E
 S
 SE
 1/4
 1/4
 1/4
 1/4