SYRACUSE CHT

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

CCA

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	Hamilton		NE-SW- Center of SW¼	17	T 24 S	R 40 W

Distance and direction from nearest town or city:
1 S. & ¼ E. of Syracuse
Street address of well location if in city:

3 Owner of well: Frank Morrell
c/o Dave Schwieterman
Address: Syracuse, KS

Locate with "X" in section below: Sketch map:

N
W E
S
1 Mile

4 Well depth: 66 ft. Date of completion 5-15-75
Well diameter 26 in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry
☒ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐

7 Casing: Material Steel Height: above/below
Threaded ☐ Welded ☒ Surface 12 in.
Diam. Weight 36 lbs./ft.
16 in. to 66 ft. depth Drive shoe? ☐ Yes ☒ No
___ in. to ___ ft. depth

2 Type and color of material	From	To
See Attached		
BROCK 6A'		
(use a second sheet if needed)		

8 Screen:
Manufacturer Johnson
Type Continuous Dia. 16"
Slot/gauze .150 Length 20'
Set between 44 ft. and 64 ft. ¼ to 1/8
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material ___

9 Static water level:
14 ft. below land surface Date 3-22-75

10 Pumping level below land surfaces: not test pumped
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date ___

12 Well head completion: 12
☐ Pitless adapter ☐ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☐ Neat cement ☒ Bentonite ☐ ___
Depth: From 0 ft. to 10 ft.

14 Nearest source of possible contamination: none observed
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☒ Not installed
Manufacturer's name ___
Model number ___ HP ___ Volts ___
Length of drop pipe ___ ft. capacity ___ g.m.p.
Type:
☐ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

16 Remarks: elevation 3212 (GPS)

Topography:
☐ Hill
☐ Slope
☐ Upland
☐ Valley
Flat

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Henkle Drilling & Supply 145
Business name License No.
Address Box 639, Garden City, KS
Signed J. W. Henkle Date 5/15/75
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Dave Schwieterman & Frank Morrell DATE 2-21-75
STREET ADDRESS TEST # 2
CITY & STATE Syracuse, Kansas DRILLER Livingston
COUNTY Hamilton QUARTER SW SECTION 17 TOWNSHIP 24 RANGE 40

LOCATION Center of the SW¼ or 1300 Ft. East of Test # 1

WELL LOCATION

Static Water Level
Proposed Well Depth

%	DRILLED from	Pay	FOOTAGE to	Description of Strata
	0		3	Top Soil
90	3	54	64	Sand fine to med. coarse; small to large gravel. Cobblestones. Lots of big gravel.
	64		66	Weathered shale
				TOTAL DEPTH OF WELL 66 Ft.
				Set up east. Dig pit on the south