

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: Fraction Section Number Township Number Range Number
 COUNTY: HAMILTON NW 1/4 SE 1/4 NE 1/4 36 T 24 S R 41 W

Distance and direction from nearest town or city street address of well if located within city?
 FROM SYRACUSE - SOUTH ON HIGHWAY 27 - 3 MILES

2 WATER WELL OWNER: FULLMER CATTLE CO. *Well #1*
 RR#, St. Address, Box #: PO BOX 986 Board of Agriculture, Division of Water Resources
 City, State, ZIP code: SYRACUSE, KS 67878- Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 365 ELEVATION: 0	
		Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.	
		WELL'S STATIC WATER LEVEL 130 ft. below land surface measured on mo/day/yr 06/18/07 Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm	
		Estimated Yield 45 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm	
		Bore Hole Diameter 10 in. to 365 ft., and in. to 0 ft.	
WELL WATER TO BE USED AS: DOMESTIC		Was a chemical/bacteriological sample submitted to department? No ; If yes, mo/day/yr sample was submitted Water well disinfected? Yes	

5 TYPE OF BLANK CASING USED: CERTA LOC CASIN CASING JOINTS: CERTA-LOC
 Blank casing diameter 5 in. to 365 ft., Dia in. to 0 ft., Dia in. to 0 ft.
 Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21 17
 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC
 SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 280 ft. to 360 ft., From 0 ft. to 0 ft.
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.
 GRAVEL PACK INTERVALS: From 25 ft. to 120 ft., From 0 ft. to 0 ft.
 From 130 ft. to 365 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE
 Grout Intervals: From 5 ft. to 25 ft., From 120 ft. to 130 ft., From 0 ft. to 0 ft.
 What is the nearest source of possible contamination: NONE
 Direction from well? How many feet? 0

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	01 TOPSOIL 10 FINE-MEDSAND			
20	40	37 FIN-COAR SAN 06 SMALL GRAVEL			
40	60	32 TAN CLAY 10 FINE-MEDSAND			
60	80	32 TAN CLAY 10 FINE-MEDSAND 32 TAN CLAY			
80	140	07 BLUE SHALE			
140	280	16 GRAY CLAY 29 SANDSTONE			
280	370	29 SANDSTONE			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 06/19/07 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 08/07/07 under the business name of JOE'S WELL SERVICE, INC. by (signature) *Joel Curt*