

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

040

| | | | | | | | | |
|---|---------------------------|--|---|---|---|--|--|--|
| 1. Location of well: | County Hamilton | Fraction SW 1/4 NE 1/4 SW 1/4 | Section number 2 | Township number T 24 S | Range number R 43 | | | |
| 2. Distance and direction from nearest town or city: 3 1/2 south 3/8 southeast of Coolidge Street address of well location if in city: | | | 3. Owner of well: Coolidge Clifford Low R.R. or street: Coolidge, KS 67836 City, state, zip code: | | | | | |
| 4. Locate with "X" in section below: | | Sketch map: | | 6. Bore hole dia. <u>26</u> in. Completion date <u>10-30-76</u> Well depth <u>116</u> ft. | | | | |
| | | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | | | |
| | | | | 9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>36.127</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>117</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gauge No. <u> </u> | | | | |
| 5. Type and color of material | | | From | To | 10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u> </u> Length <u>30'</u> Set between <u>82</u> ft. and <u>112</u> ft. <u>Peris 50-82</u> ft. and <u>112-116</u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/4" Down</u> | | | |
| (Use a second sheet if needed) | | | | | 11. Static water level: <u>38</u> ft. below land surface Date <u>9-25-76</u> mo./day/yr. | | | |
| | | | | | 12. Pumping level below land surfaces: <u>47</u> ft. after <u>3</u> hrs. pumping <u>1450</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1450</u> g.p.m. | | | |
| | | | | | 13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u> | | | |
| | | | | | 14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade | | | |
| | | | | | 15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft. | | | |
| | | | | | 16. Nearest source of possible contamination: <u>N/A=</u> <u>Field MC</u> ft. <u> </u> Direction <u> </u> Type <u>Field MC</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | | |
| | | | | | 17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds U.S Pumps</u> Model number <u>12 JLO</u> HP <u>60</u> Volts <u> </u> Length of drop pipe <u>100</u> ft. capacity <u>100</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | | |
| | | | 18. Elevation: | 19. Remarks: 60 HP electric motor & panel 3368 (TOPC) | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. <u> </u> Address <u>Box A Garden City, KS 67844</u> Signed <u>[Signature]</u> Date <u>2-24-77</u> Authorized representative | | |

24 430 - 2 SW NE SW
 T R Sec 1/4

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CLIFFORD LOW
HAMILTON COUNTY
8-28-76

Location: SH $\frac{1}{2}$ 2-24-43 3 3/4 south of Coolidge
East 20 Ft, north pivot
Static Water Level- 35-40

Test #2

| | | |
|-----|-----|------------------------------|
| 0 | 8 | Top soil fine sand |
| 8 | 10 | Brown sandy clay |
| 10 | 23 | Med. coarse gravel |
| 23 | 85 | Coarse gravel |
| 85 | 112 | Coarse gravel hard pull down |
| 112 | 115 | Shale hard pull down |

T.D. 116'