


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Hamilton	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 3	Township number T 24 S R 43 24	Range number 43 24
2. Distance and direction from nearest town or city: 3 1/2 south, 1/2 west 3/8 southwest of Coolidge Street address of well location if in city:			3. Owner of well: Clifford Low R.R. or street: Coolidge, KS 67836 City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. 26 in. Completion date 10-1-76 Well depth 136 ft.	
5. Type and color of material			From		To	
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 137 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 30' Set between 100 ft. and 130 ft. Perf: 60-100 ft. and 130-136 ft. Gravel pack? yes Size range of material 1/2" Down			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 36 ft. below land surface Date 9-28-76			
			12. Pumping level below land surfaces: 48 ft. after 3 hrs. pumping 1350 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1350 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Flow Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No						
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds U.S. Pumps Model number 12 JLN HP 60 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
(Use a second sheet if needed)						
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 60 HP electric motor & panel					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name License No. Address Box A Garden City, KS 67846 Signed <i>[Signature]</i> Date 1-24 Authorized representative						

24
 43
 24
 30
 3
 SW
 46
 NE
 SW
 Sec
 1/4
 1/4

DURKEE CREEK NE

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846
CLIFFORD LOW
HAMILTON COUNTY
8-28-76

Location: SW 3-24-43 south of Coolidge 3 1/2 and 3/4
west 1/2 south 20 Ft. north of pivot
Static Water Level- 40-45

Test #1

0	1	Top soil
1	6	Fine sand
6	15	Brown sandy clay
15	22	Med. coarse gravel
22	132	Coarse gravel
132	134	Yellow shale hard pull down

T.S. 136

BROCK 132'

CAC