

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Hamilton</b>	Fraction <b>NE 1/4 NE 1/4 NW 1/4</b>	Section number <b>10</b>	Township number <b>T 24 S R 43</b>	Range number <b>43</b>	<b>W</b>
2. Distance and direction from nearest town or city: <b>Johnson, Ks. 17 miles north, 14 west, 11 1/2 north the southwest into field</b>				3. Owner of well: <b>Clifford Seay</b> R.R. or street: <b>Lakin, Ks. 67860</b> City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>27</u> in. Completion date _____ Well depth <u>120.7</u> <u>4/20/77</u>			
		<p>7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material <u>steel</u> Height <u>Above</u> or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>14</u> in. RMP _____ PVC _____ Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>60.2</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. <u>219</u></p>		10. Screen: Manufacturer's name _____ <u>Lakewood Pipe of Texas</u> Type <u>steel</u> Dia. <u>16"</u> Slot/gauze <u>3/16"</u> Length <u>60.5'</u> Set between <u>60.2</u> ft. and <u>120.7</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 x 5/8"</u>			
				11. Static water level: _____ mo./day/yr. <u>40</u> ft. below land surface Date <u>4-12-77</u>			
5. Type and color of material		From	To	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. <u>57.6'</u> ft. after <u>5.3</u> hrs. pumping <u>1700</u> g.p.m. Estimated maximum yield _____ g.p.m. <u>3000</u>			
Surface		0	2	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
Brown clay & sand		2	105	14. Well head completion: <u>5ft</u> <input type="checkbox"/> Pitless adapter _____ inches above grade			
Blue & brown clay and sand		105	120	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>field</u> Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Houck Bros. Drilling Co. 164</u> Business name _____ License No. _____ Address <u>Box 487, Ulysses, Ks.</u> Signed <u>M. Beard</u> Date <u>5/27</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

24 430 10 NE NE NW  
 T R Sec  
 1/4 1/4 1/4