


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


HAC

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Hamilton</u>		Fraction <u>SW NE</u> <u>NE 1/4 SW 1/4 NE 1/4</u>		Section number <u>10</u>		Township number <u>T 24 S R</u>		Range number <u>43/W</u>	
2. Distance and direction from nearest town or city: <u>3 1/8 southwest of Coolidge</u>				4 south, <u>4 south,</u>		3. Owner of well: David W. Tapscott R.R. or street: 1122 San Juan City, state, zip code: <u>La Junta Colo. 81050</u>			
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. <u>20</u> in. Completion date <u>10-20-76</u> Well depth <u>90</u> ft.		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material				From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
								9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>01</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>	
								10. Screen: Manufacturer's name <u>Johnson</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <input type="checkbox"/> Length <u>30'</u> Set between <u>55</u> ft. and <u>85</u> ft. Perf: <u>50-55</u> ft. and <u>85-90</u> ft. Gravel pack? <input checked="" type="checkbox"/> size range of material <u>1/2" Down</u>	
								11. Static water level: <u>47</u> ft. below land surface Date <u>10-4-76</u> mo./day/yr.	
								12. Pumping level below land surfaces: <u>56</u> ft. after <u>3</u> hrs. pumping <u>1325</u> p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>1325</u> g.p.m.	
								13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
								14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade	
								15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
								16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <u>Field</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
								17. Pump: Manufacturer's name <u>Goulds U.S. Pumps</u> Not installed Model number <u>12 JHN</u> HP <u>50</u> Volts <input type="checkbox"/> Length of drop pipe <u>80</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)									
18. Elevation:		19. Remarks: <u>50 HP Electric motor and panel-part wind</u>						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling</u> Business name License No. <input type="checkbox"/> Address <u>Box A Garden City, KS</u> Signed <u>[Signature]</u> Date <u>2-28-77</u> Authorized representative	

247
 T
 14
 R
 30
 10
 Sec
 1/4 NE SW NE



DURKEE CREEK NE

MINTER-WILSON DRILLING CO. INCORPORATED Irrigation and Domestic Water Systems Complete Installation and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TAPSCOTT
HAMILTON COUNTY
9-22-76

Location: NE form Coolidge 4 south 3/10 of a mile
west 300 Ft south from pivot fo 2/10 north
300 Ft west

Static Water Level- 40'

Test #1

- 0 1 Top soil
- 1 6 fine sand
- 6 22 Brown clay
- 22 33 Med. coarse gravel clay trace loose
- 33 39 Coarse gravel tight
- 39 43 Coarse gravel clay trace
- 43 55 Coarse gravel Loose
- 55 85 Coarse gravel
- 35 90 Yellow clay
- 90 95 Shale

BROCK 85'

AAC