

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County RENO	Fraction 1/4 SW 1/4 SE 1/4	Section number 1	Township number T 24 S	Range number R 5W E/W
2. Distance and direction from nearest town or city: 6 North of Haven, Street address of well location if in city: 2 1/2 West of Haven, Ks.			3. Owner of well: Richard Seck R.R. or street: Haven, Kansas City, state, zip code:			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. 14 in. Completion date 6-16-77 Well depth 35 ft.	
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Fine Sand			0	5	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Coarse Sand and Fine Gravel			5	35	9. Casing: Material PVC Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 5.47 in. RMP 8 PVC <input checked="" type="checkbox"/> Weight 5.47 lbs./ft. Dia. 8 in. to 35 ft. depth Wall thickness .332 inches or Dia. 8 in. to 35 ft. depth gage No. .332	
					10. Screen: Manufacturer's name PVC NSF approved 160 PSI Type PVC 160PSI Dia. 8" Slot .06 Length 25' Set between 10 ft. and 35 ft. Gravel pack? yes Size range of material 1/4-1/8"	
					11. Static water level: 5 ft. below land surface Date 6-15-77	
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					13. Water sample submitted: ____ mo./day/yr. ____ Yes <input checked="" type="checkbox"/> No Date ____	
					14. Well head completion: 12 capped ____ Pitless adapter ____ inches above grade	
					15. Well grouted? yes 1-2 fine sand mix With: 0 Neat cement 10 Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: NONE ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks: Flat Ground No apparent source for contamination.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. ____ Address ____ Signed M. Arneel Date 6-30-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5