


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County RENO	Township name Yoder	Fraction SWSWSE	Section number 5	Town number T-24-S	Range number RSW
Distance and direction from nearest town or city: 4 mi S 2 1/2 E				3 Owner of well: Russell Baggett		
Street address of well location if in city: of Hutchinson				Address: R2 Hutchinson, Ks. 67501		
Locate with "X" in section below:		Sketch map:		4 Well depth: 52 ft. Date of completion 6-25-75 Well diameter 10 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material PVC Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 76 in. Diam. 6 in. Weight 160 lbs./ft. 6 in. to 52 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
2		Type and color of material		From	To	8 Screen: Manufacturer Corlan Type PVC Dia. 6 Slot/mauze 3/16 Length 10' Set between 42 ft. and 52 ft. Fittings: rd gravel Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material
		Yellow clay		0	19	9 Static water level: 20 ft. below land surface Date 6-24-75
		Fine sand		19	22	10 Pumping level below land surfaces: 32 ft. after 1 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 35 g.p.m.
		Yellow clay		22	32	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
		Fine sand		32	36	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
		Yellow clay		36	40	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 4 ft. to 14 ft.
		Coarse sand		40	52	14 Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
(use a second sheet if needed)				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Valley Model number S1268 HP 1 1/2 Volts 230 Length of drop pipe 35 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation New House located in field. No septic system installed yet.				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well 137 Business name Hutchinson, Ks License No. Address Go E Miller Date 7-6-75 Signed Go E Miller Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5