

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 21	Township number T 24 S R 5 E	Range number 5
2. Distance and direction from nearest town or city: Located in			3. Owner of well: Bertha Troxor			
Street address of well location if in city: No Street address			City, state, zip code: Yoder, KS			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 10 in. Completion date 10-30-79	
		House Septic			Well depth 58 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material plst Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.58 lbs./ft. Dia. 6 in. to 58 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 280	
5. Type and color of material		From	To			
Bl Top Soil		0	4			
Br Clay		4	45			
F + C Sand		45	57			
Br Clay		57	59			
				10. Screen: Manufacturer's name Jet Stream		
				Type PVC Dia. 6"		
				Slot/gauze .030 Length 10'		
				Set between 48 ft. and 58 ft.		
				Gravel pack? Yes Size range of material F-1/2		
				11. Static water level: 34 ft. below land surface Date 10-1-79		
				12. Pumping level below land surfaces:		
				38 ft. after 2 hrs. pumping 20 g.p.m.		
				40 ft. after 40 hrs. pumping 40 g.p.m.		
				Estimated maximum yield 40 g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 10-1-79		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 Inches above grade		
				15. Well grouted? Yes		
				With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete		
				Depth: From 3 ft. to 15 ft.		
				16. Nearest source of possible contamination: 60 ft. Direction NE Type septic		
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed		
				Manufacturer's name Valley		
				Model number 51208 HP 1/2 Vol 230		
				Length of drop pipe 40 ft. capacity 40 g.p.m.		
				Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
				<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
				<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well 382 Business name License No. Address Hutch, KS Signed Egan Miller Date 2-4-80 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5