

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Reno	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 31	Township number T 24	Range number S R 5	E 10
2. Distance and direction from nearest town or city: 1-S. 1-W. of Hwy 17 & Yoder Rd Street address of well location if in city: S. of Hutchinson			3. Owner of well: Charles Stephenson R.R. or street: RR #2 City, state, zip code: Hutchinson Kan. 67501			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 12 in. Completion date 8-25-76 Well depth 52 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material Plas Height: 60 or below Threaded <input type="checkbox"/> Welded 6 1/2 Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 6 in. to 52 ft. depth Wall Thickness: 1/8 in. or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 1175	
					10. Screen: Manufacturer's name J&L Type RMP Dia. 6 " Slot/gauze 1/8 hole Length 25 Set between 27 ft. and 52 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/8-1/2	
					11. Static water level: <input type="checkbox"/> ft. below land surface Date 8-25-76 mo./day/yr.	
					12. Pumping level below land surfaces: 22 ft. after 1 hrs. pumping 15 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 20 g.p.m.	
(Use a second sheet if needed)					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.	
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
					16. Nearest source of possible contamination: ft. 60 Direction N Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Price Water Well 193 Business name RR3 Hutchinson License No. <input type="checkbox"/> Address John Davenport Date 7-21-77 Signed John Davenport Authorized representative				

24-5037 NW 1/4 NW 1/4
 Sec 37
 R 5
 T 24