


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 5	Township number T 24 S R 6 W E/W	Range number
2. Distance and direction from nearest town or city: 2 1/2 S 3 1/2 W of S. Hutchinson, Ks.			3. Owner of well: O.O. Amish Church R.R. or street: c/o John Headings City, state, zip code: Rt. 1 Hutchinson, Ks. 67501			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 10/30/76 Well depth 45 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
topsoil		0 3		9. Casing: Material plst Height: Above xxx below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.95 lbs./ft. Dia. 6 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200		
clay yellow		3 8		10. Screen: Manufacturer's name J&L Type RMP Dia. 6" Slot/gauze 3/32 Length 10' Set between 35 ft. and 45 ft. ft. and <input type="checkbox"/> ft.		
clay/silt yellow		8 12		Gravel pack? yes Size range of material 1/2"		
sand fine		12 17		11. Static water level: 28.5 ft. below land surface Date 10/30/76 mo./day/yr.		
sand coarse yellow		12 45		12. Pumping level below land surfaces: 30 ft. after 1 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 40 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: 70 ft. Direction NE Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Valley Model number 50612 HP 1/2 Volts 230 Length of drop pipe 33 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well Serv. 137 Business name License No. Address Hutchinson, Ks. Signed [Signature] 11/30/76 Date Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5