

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Reno	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 7	Township number T 24 S	Range number R 6 W E/W
2. Distance and direction from nearest town or city: 3m E 1/4 N of Partridge, Ks.			3. Owner of well: Ora Nisly Rt. 1 Hutchinson, Ks. 67501		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			From	To	
			6. Bore hole dia. <u>10</u> in. Completion date <u>11/1/76</u> Well depth <u>52</u> ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>plst</u> Height: Above or <u>below</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.95</u> lbs./ft. Dia. <u>6</u> in. to <u>52</u> ft. depth Wall Thickness: inches or Dia. <u>6</u> in. to <u>52</u> ft. depth gage No. <u>.200</u>		
			10. Screen: Manufacturer's name <u>J&L</u> Type <u>RMP</u> Dia. <u>6"</u> Slot/gauze <u>3/32</u> Length <u>10"</u> Set between <u>42</u> ft. and <u>52</u> ft. Set between <u>42</u> ft. and <u>52</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>R-1/2"</u>		
			11. Static water level: <u>28</u> ft. below land surface Date <u>11/1/76</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>29.5</u> ft. after <u>1</u> hrs. pumping <u>20</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>50</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>yes</u> With: <u>4</u> Neat cement <u> </u> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u> </u> ft. to <u>14</u> ft.		
			16. Nearest source of possible contamination: ft. <u>55</u> Direction <u>W</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <u>Valley</u> Not installed Manufacturer's name <u>Valley</u> Model number <u>S0812MF</u> HP <u>1</u> Volts <u>230</u> Length of drop pipe <u>35</u> ft. capacity <u>12</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well Serv. 137 Business name <u>Hutchinson, Ks.</u> License No. <u> </u> Address <u> </u> Signed <u>J. Miller</u> 11/1/76 Date <u> </u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5