

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Reno		Fraction NW 1/4 NW 1/4 SW 1/4	Section number 18	Township number T 24 S R 6	Range number 6
2. Distance and direction from nearest town or city: 3 mi E, 1/2 S of Partridge, KS			3. Owner of well: Sylvia Fisher R.R. or street: Rt 1 City, state, zip code: Hutchinson, KS 67501		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 9-28-79 Well depth 41 ft.	
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Black Top Soil		0	3	9. Casing: Material PLST Height Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.58 lbs./ft. Dia. 6 in. to 41 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 280	
Light Gr Silt		3	8	10. Screen: Manufacturer's name Pumpco Type PVC Dia. 6" Perforations 1030 Length 10' Set between 31 ft. and 41 ft. Gravel pack? Yes Size range of material E-1/4	
F+C Sand		8	18	11. Static water level: 12 ft. below land surface Date 9-28-79 mo./day/yr.	
Gr Clay		18	20	12. Pumping level below land surfaces: 16 ft. after 2 hrs. pumping 20 g.p.m. 28 ft. after 4 hrs. pumping 40 g.p.m. Estimated maximum yield 40 g.p.m.	
F+C Sand		20	28	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 9-28-79 mo./day/yr.	
Sand & Gravel		28	43	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 100 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Valley Model number 51206 HP 1/3 Volts 270 Length of drop pipe 20 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well 382 Business name Hutch, KS License No. Address Hutch, KS Signed Egan Miller Date 9-4-80 Authorized representative	
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5