

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Reno	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 16	Township number T 24 S R 7	Range number EW
2. Distance and direction from nearest town or city: N Edge of town			3. Owner of well: Ira Miller			
Street address of well location if in city: Partridge, KS			City, state, zip code: Partridge, KS 67566			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 10 in. Completion date 3-29-76 Well depth 40 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	3	9. Casing: Material Plst Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 15 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 1.95 lbs./ft. Dia. 6 in. to 40 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200		
Yellow clay		3	7	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 6" Slot gauze 3/32 Length 10' Set between 30 ft. and 40 ft. ft. and ft. Gravel pack? yes Size range of material 1/4 x 1/2		
Gray clay		7	16	11. Static water level: 22 ft. below land surface Date 3-30-74 mo./day/yr.		
Coarse sand & Gravel		16	40	12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 3.5 g.p.m.		
				13. Water sample submitted: X Yes <input type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 15 Inches above grade		
				15. Well grouted? yes With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. 70 Direction South Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Miller Water Well Serv 137 Business name License No. Address 1539 W 4th, Hutchinson Signed Ira Miller Date 8-15-76 Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5