


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction SE¹/₄ SE¹/₄ NW¹/₄	Section number 13	Township number T 25 S R 1	Range number 1 (EW)
2. Distance and direction from nearest town or city: Street address of well location if in city: 2 East, 1/2 N Colwich			3. Owner of well: Georges Bros. R.R. or street: City, state, zip code: Colwich, Kansas 67030			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 			6. Bore hole dia. 30 in. Completion date 7/30/76 Well depth 97 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Topsoil		0	1	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine Sand w/clay		1	15	9. Casing: Material C-Asb Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/4 in. to 58 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 3/4"		
Sand		15	25	10. Screen: Manufacturer's name Johnson Type Cement-Asbestos Dia. 1 1/4" Slot/gauze 1/4" Length Set between 58 ft. and 97 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 3/8		
Coarse Sand with clay		25	40	11. Static water level: <input type="checkbox"/> mo./day/yr. 17 ft. below land surface Date 7/30/76		
Med. Gravel		40	60	12. Pumping level below land surfaces: 30 ft. after 2 hrs. pumping 400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1250 g.p.m.		
Bad Gravel		60	97	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 1500 Direction NW Type Domestic Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless Model number 6087 HP <input type="checkbox"/> Volts Length of drop pipe 70 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weninger Drilling 238 Business name Maize, Kans. 67101 License No. Address H. Weninger Date 8/23/76 Signed H. Weninger Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

R 5 - L 13 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3