


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGEWICK	Fraction 1/4 NW 1/4 NE 1/4	Section number 27	Township number T 25 S R 1W E/W	Range number
2. Distance and direction from nearest town or city: 2 miles West of Valley Center, Ks.		3. Owner of well: Bill Grattan		R.R. or street: 5400 W 85 No.		
Street address of well location if in city: 3/4 mile No. of 85th So.		City, state, zip code: Valley Center, Ks.				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 4-17-79 Well depth 120 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Topsoil		0	2	9. Casing: Material Transite Height: Above or below See #19 Below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 120 ft. depth Wall Thickness: inches or Dia. 3/4 in. to 3/4 ft. depth Gauge No. 3/4		
Clay		2	6	10. Screen: Manufacturer's name Johnson Type irrigator Dia. 16" Slot 1/16 in. 100 Length 67' Set between 40-53 ft. and 57-70 ft. 79-120 ft. and 120 ft.		
Fine Sand and Gravel		6	11	Gravel pack? yes Size range of material 1/4-1/8"		
Blue Clay		11	17	11. Static water level: 17 1/2 ft. below land surface Date 4-17-79 mo./day/yr.		
Medium to Coarse Sand and Gravel		17	54	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Clay		54	60	<input checked="" type="checkbox"/> Water sample submitted: yes mo./day/yr. Yes No Date		
Fine to Coarse Sand and Gravel		60	72	14. Well head completion: 12 Capped Pitless adapter 12 inches above grade		
Clay		72	74	15. Well grouted? yes 1-2 Fine Sand Mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Fine to Coarse Sand and Fine to Medium Gravel with some Clay		74	100	16. Nearest source of possible contamination: NONE ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes No		
Clay		100	104	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Fine to Coarse Sand		104	110			
Clay and Sandstone with some Sand		110	120			
(Use a second sheet if needed)						
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Replacement well- referring to # 8 above Flat Ground No Apparent source for Contamination From #9 Above- Banded But Joint Customer Furnished his own pump.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump Serv. 236 Business name Wichita, Kans. License No. Address Signed M. Arnold Date 5-3-79 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5