

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: <u>Sedgewick</u>		<u>SW 1/4 SE SW 1/4</u>	<u>33</u>	<u>25</u> S	<u>1</u> E
Distance and direction from nearest town or city street address of well if located within city? <u>See Below</u>					
2 WATER WELL OWNER: <u>Shawn Allen</u>					
RR#, St Address, Box #: <u>7503 W. 85th North</u>					
City, State, ZIP Code: <u>Wichita, KS</u>					
Board of Agriculture, Division of Water Resources Application Number: _____					
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL			
		ft. ELEVATION: <u>46</u>			
		Depth(s) Groundwater Encountered <u>18</u> ft. 2. _____ ft. 3. _____ ft.			
		WELL'S STATIC WATER LEVEL <u>18</u> ft. below land surface measured on <u>9/25/94</u> mo/day/yr			
		Pump test data: Well water was <u>20</u> ft. after <u>1/2</u> hours pumping <u>20</u> gpm			
		Est. Yield <u>20</u> gpm Well water was _____ ft. after _____ hours pumping _____ gpm			
Bore Hole Diameter <u>11</u> in. to <u>46</u> ft. and _____ in. to _____ ft.					
WELL WATER TO BE USED AS:					
☒ 1 Domestic ☐ 3 Feedlot ☐ 6 Oil field water supply ☐ 9 Dewatering ☐ 12 Other (Specify below) ☐ 2 Irrigation ☐ 4 Industrial ☐ 7 Lawn and garden only ☐ 10 Monitoring well					
Was a chemical/bacteriological sample submitted to Department? Yes _____ No <u>X</u> If yes, mo/day/yr sample was submitted _____					
Water Well Disinfected? Yes <u>X</u> No _____					
5 TYPE OF BLANK CASING USED:					
☒ 1 Steel ☐ 3 RMP (SR) ☐ 5 Wrought iron ☐ 8 Concrete tile CASING JOINTS: Glued <u>X</u> Clamped _____ ☒ 2 PVC ☐ 4 ABS ☐ 6 Asbestos-Cement ☐ 9 Other (specify below) Welded _____ ☐ 7 Fiberglass Threaded _____					
Blank casing diameter <u>5</u> in. to <u>12</u> ft. Dia _____ in. to _____ ft. Dia _____ in. to _____ ft.					
Casing height above land surface <u>12</u> in. weight <u>2.60</u> lbs./ft. Wall thickness or gauge No. <u>160 RSI</u>					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
☐ 1 Steel ☐ 3 Stainless steel ☐ 5 Fiberglass ☒ 7 PVC ☐ 10 Asbestos-cement ☐ 2 Brass ☐ 4 Galvanized steel ☐ 6 Concrete tile ☐ 8 RMP (SR) ☐ 11 Other (specify) _____ ☐ 12 None used (open hole)					
SCREEN OR PERFORATION OPENINGS ARE:					
☐ 1 Continuous slot ☒ 3 Mill slot ☐ 5 Gauzed wrapped ☐ 8 Saw cut ☐ 11 None (open hole) ☐ 2 Louvered shutter ☐ 4 Key punched ☐ 6 Wire wrapped ☐ 9 Drilled holes ☐ 7 Torch cut ☐ 10 Other (specify) _____					
SCREEN-PERFORATED INTERVALS: From <u>40</u> ft. to <u>46</u> ft. From _____ ft. to _____ ft.					
GRAVEL PACK INTERVALS: From <u>20</u> ft. to <u>46</u> ft. From _____ ft. to _____ ft.					
6 GROUT MATERIAL:					
☒ 1 Neat cement ☒ 2 Cement grout ☐ 3 Bentonite ☐ 4 Other _____ Grout intervals: From <u>3</u> ft. to <u>18</u> ft. From _____ ft. to _____ ft. From _____ ft. to _____ ft.					
What is the nearest source of possible contamination:					
☒ 1 Sepsic tank ☐ 4 Lateral lines ☐ 7 Pit privy ☐ 10 Livestock pens ☐ 14 Abandoned water well ☐ 2 Sewer lines ☐ 5 Cess pool ☐ 8 Sewage lagoon ☐ 11 Fuel storage ☐ 15 Oil well/Gas well ☐ 3 Watertight sewer lines ☐ 6 Seepage pit ☐ 9 Feedyard ☐ 12 Fertilizer storage ☐ 16 Other (specify below) ☐ 13 Insecticide storage					
Direction from well? <u>South</u> How many feet? <u>60</u>					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<u>0</u>	<u>2</u>	<u>Top Soil</u>			
<u>2</u>	<u>16</u>	<u>Clay</u>			
<u>16</u>	<u>31</u>	<u>fine sand</u>			
<u>31</u>	<u>32</u>	<u>clay</u>			
<u>31</u>	<u>46</u>	<u>gravel</u>			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was <u>(1)</u> constructed, <u>(2)</u> reconstructed, or <u>(3)</u> plugged under my jurisdiction and was completed on (mo/day/year) <u>9-25-94</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>318</u> This Water Well Record was completed on (mo/day/yr) <u>10-3-94</u> under the business name of <u>Weninger Drilling</u> by (signature) <u>Karrina Morrissey</u>					