

1 LOCATION OF WATER WELL:	Fraction Near Center	Section Number	Township Number	Range Number
County: <u>Stafford</u>	$\frac{1}{4}$ $\frac{1}{4}$ NE $\frac{1}{4}$	<u>19</u>	T <u>25</u> S	R <u>11</u> E <u>N</u>

Distance and direction from nearest town or city street address of well if located within city?

Approximately 3 miles West of Neola, KS

2 WATER WELL OWNER: <u>James Dickson</u>	Board of Agriculture, Division of Water Resources
RR#, St. Address, Box # : <u>Rt. 1 Box 67</u>	Application Number: <u>39,000</u>
City, State, ZIP Code : <u>Stafford, KS 67578</u>	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: <u>104</u> ft. ELEVATION: <u>unknown</u>
	Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL <u>28</u> ft. below land surface measured on mo/day/yr Pump test data: Well water was <u>not ch'd</u> ft. after hours pumping gpm Est. Yield <u>unknown</u> gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter <u>16</u> in. to <u>104</u> ft., and in. to ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 <u>Irrigation</u> 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes.....No <u>X</u>; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes No <u>X</u>

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued Clamped
1 <u>Steel</u>	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below) Welded <u>X</u>
2 <u>PVC</u>	4 <u>ABS</u>	7 Fiberglass	Threaded
Blank casing diameter <u>16</u> in. to <u>39</u> ft., Dia <u>16</u> in. to <u>84</u> ft., Dia in. to ft.			
Casing height above land surface <u>12</u> in., weight <u>42.05</u> lbs./ft. Wall thickness or gauge No. <u>250</u>			
TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC	10 Asbestos-cement	
1 <u>Steel</u>	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 <u>Brass</u>	4 Galvanized steel	6 Concrete tile	9 <u>ABS</u>
SCREEN OR PERFORATION OPENINGS ARE:	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 <u>Continuous slot</u>	3 Mill slot	6 Wire wrapped	9 Drilled holes
2 <u>Louvered shutter</u>	4 Key punched	7 Torch cut	10 Other (specify)
SCREEN-PERFORATED INTERVALS: From <u>39</u> ft. to <u>59</u> ft., From ft. to ft.			
From <u>84</u> ft. to <u>104</u> ft., From ft. to ft.			
GRAVEL PACK INTERVALS: From <u>20</u> ft. to <u>104</u> ft., From ft. to ft.			
From ft. to ft., From ft. to ft.			

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grout Intervals: From <u>0</u> ft. to <u>20</u> ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:	10 Livestock pens	14 Abandoned water well		
1 Septic tank	4 Lateral lines	7 Pit privy	11 Fuel storage	15 Oil well/Gas well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	12 Fertilizer storage	16 Other (specify below)
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	13 Insecticide storage	None Known
Direction from well?	How many feet?			

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	3	Topsoil, sandy			
3	22	Clay, brown sandy			
22	25	Sand fine			
25	32	Clay brown			
32	59	Sand and Gravel fine med. to coarse			
59	72	Clay tan, thin streaks of sandstone			
72	76	Sand fine			
76	85	Clay, brown sandy			
85	104	Sand and Gravel fine med.			
104		Clay greenish brown			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>5/26/89</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>185</u> This Water Well Record was completed on (mo/day/yr) <u>5/30/89</u> under the business name of <u>XXXX Clarke Well & Equipment</u> by (signature) <u>[Signature]</u>
