

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: Stafford		sw 1/4 ne 1/4 sw 1/4		31		T 25 S		R 11w E/W	
Distance and direction from nearest town or city? 3s 3 3/4w Neola, Ks.					Street address of well if located within city?				
2 WATER WELL OWNER: Merckle Drlg Co					Board of Agriculture, Division of Water Resources				
RR#, St. Address, Box #: Box 1382					Application Number: unknown				
City, State, ZIP Code: Great Bend, Ks. 67530									
3 DEPTH OF COMPLETED WELL: 80 ft. Bore Hole Diameter: 8 in. to 80 ft. and 80 in. to 80 ft.									
Well Water to be used as:					11 Injection well				
1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 9 Dewatering 12 Other (Specify below)									
2 Irrigation 4 Industrial 6 Oil field water supply 7 Lawn and garden only 10 Observation well									
Well's static water level 30 ft. below land surface measured on 1 month 9 day 79 year									
Pump Test Data					Well water was 1 ft. after 9 hours pumping 79 gpm				
Est. Yield 60 gpm: Well water was 1 ft. after 9 hours pumping 79 gpm									
4 TYPE OF BLANK CASING USED:					Casing Joints: <u>Glued</u> Clamped				
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile					Welded				
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below)					Threaded				
3 Fiberglass									
Blank casing dia 5 in. to 60 ft. Dia 60 in. to 60 ft. Dia 60 in. to 60 ft. Dia									
Casing height above land surface 12 in., weight 2.8 lbs./ft. Wall thickness or gauge No Sch 40									
TYPE OF SCREEN OR PERFORATION MATERIAL:					7 PVC 10 Asbestos-cement				
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)									
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)									
Screen or Perforation Openings Are:					5 Gauzed wrapped 8 Saw cut 11 None (open hole)				
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes									
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)									
Screen-Perforation Dia 5 in. to 60 ft. Dia 60 in. to 80 ft. Dia 80 in. to 80 ft. Dia									
Screen-Perforated Intervals: From 60 ft. to 80 ft. From 80 ft. to 80 ft. From 80 ft. to 80 ft. From 80 ft. to 80 ft.									
Gravel Pack Intervals: From 10 ft. to 80 ft. From 80 ft. to 80 ft. From 80 ft. to 80 ft. From 80 ft. to 80 ft.									
5 GROUT MATERIAL:					3 Bentonite 4 Other				
1 Neat cement 2 Cement grout									
Grouted Intervals: From 0 ft. to 10 ft. From 10 ft. to 10 ft. From 10 ft. to 10 ft. From 10 ft. to 10 ft.									
What is the nearest source of possible contamination:					10 Fuel storage 14 Abandoned water well				
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well									
2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)									
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines									
Direction from well se How many feet 80 ? Water Well Disinfected? Yes No									
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample									
was submitted month day year Pump Installed? Yes No									
If Yes: Pump Manufacturer's name Model No. HP Volts									
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.									
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was									
completed on 1 month 9 day 79 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 186									
This Water Well Record was completed on 2 month 26 day 80 year under the business									
name of Kellys Waterwell Serv. by (signature) <i>Kelly Price</i>									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG		FROM TO		LITHOLOGIC LOG	
		0# 30		Top Soil-Clay					
		30 40		Sand					
		40 53		Clay					
		53 80		Sand-Gravel					
ELEVATION: unknown									
Depth(s) Groundwater Encountered 1. 30 ft. 2. 30 ft. 3. 30 ft. 4. 30 ft. (Use a second sheet if needed)									

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.