

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Stafford</b>	Fraction 1/4 <b>CSW/4</b>	Section number <b>10</b>	Township number T <b>25</b> S R <b>13</b> <b>1/W</b>	Range number
2. Distance and direction from nearest town or city: <b>8 S.</b>			3. Owner of well: <b>DON DUDREY</b>			
Street address of well location if in city: <b>ST JOHN, KS</b>			R.R. or street: <b>1900 HARRISON</b>			
			City, state, zip code: <b>Great Bend, KS</b>			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. <b>30</b> in. Completion date Well depth <b>91</b> ft. <b>6-16-77</b>	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<b>Top Soil - Clay</b>			<b>0</b>	<b>40</b>	9. Casing: Material <b>Steel</b> Height: Above <del>surface</del> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>24</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <b>16</b> in. to <b>51</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>3/16"</b>	
<b>Sand - Gravel</b>			<b>40</b>	<b>91</b>	10. Screen: Manufacturer's name <b>Doery</b> Type <b>Steel</b> Dia. <b>16"</b> Slot/gauze <b>1/8"</b> Length <b>40'</b> Set between <b>51</b> ft. and <b>91</b> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/8-3/4"</b>	
					11. Static water level: _____ mo./day/yr. <b>19</b> ft. below land surface Date <b>6-16-77</b>	
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. <b>71</b> ft. after <b>4</b> hrs. pumping <b>1200</b> g.p.m. Estimated maximum yield _____ g.p.m. <b>1200</b>	
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
					14. Well head completion: <input type="checkbox"/> Pitless adapter <b>24</b> Inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
					16. Nearest source of possible contamination: <b>NONE</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
					17. Pump: _____ Not installed Manufacturer's name <b>Qualls</b> Model number <b>4123</b> HP <b>80</b> Volts _____ Length of drop pipe <b>80</b> ft. capacity <b>1000</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>186</b> <b>Kellys Waterwell ser</b> Business name _____ License No. _____ Address <b>R2 Great Bend, KS</b> Signed <b>Kelly Price</b> Date <b>7-28-78</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

25  
13  
10  
1/4  
1/4  
1/4  
CSW