

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

Polin #1

1. Location of well: County Stafford Fraction SE 1/4 NE 1/4 SE 1/4 Section number 28 Township number T 25 S Range number R 13 W E/W

2. Distance and direction from nearest town or city: 1 1/2 miles south St. John
Street address of well location if in city: _____
3. Owner of well: Search, Drilling Co
R.R. or street: Michita Kansas
City, state, zip code: _____

4. Locate with "X" in section below:
Sketch map:
N
W E
SW SE
S
1 Mile

6. Bore hole dia. 8 in. Completion date 12-11-75
Well depth 70 ft.
7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary
8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other
9. Casing: Material Plastic Height: above or below
Threaded Welded Surface 12 in.
RMP PVC Weight 224 lbs./ft.
Dia. 5 in. to 20 ft. depth Wall Thickness: inches or
Dia. 5 in. to 20 ft. depth gage No. 200

5. Type and color of material	From	To
<u>Clay</u>	<u>0</u>	<u>12</u>
<u>Sandy clay</u>	<u>12</u>	<u>30</u>
<u>Sand</u>	<u>30</u>	<u>50</u>
<u>Gravel</u>	<u>50</u>	<u>70</u>

10. Screen: Manufacturer's name Pitless Plastic
Type PVC Dia. 5
Sizing gauze 50 Length 20
Set between 50 ft. and 70 ft.
ft. and _____ ft.
Gravel pack? Yes Size range of material 3-4
11. Static water level: _____ mo./day/yr.
12 ft. below land surface Date 12-17-75
12. Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.
13. Water sample submitted: _____ mo./day/yr.
Yes No Date _____
14. Well head completion:
_____ Pitless adapter _____ Inches above grade
15. Well grouted? Yes
With: _____ Neat cement Bentonite _____ Concrete
Depth: From 0 ft. to 10 ft.
16. Nearest source of possible contamination:
ft. _____ Direction _____ Type _____
Well disinfected upon completion? _____ Yes _____ No
17. Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation:
Topography:
 Hill
 Slope
 Upland
 Valley
19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Myers Water Well 143
Business name _____ License No. _____
Address Great Bend, KS
Signature Alfred Myers Date 12-17-75
Authorized representative

T 25 S R 13 W S 28 SE 1/4 NE 1/4 SE