

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Stafford		Fraction 1/4 1/4 CSE 1/4	Section number 15	Township number T 25 S R 14 E 0	Range number 14
2. Distance and direction from nearest town or city: 7.5 SW			3. Owner of well: DON FISHER		
Street address of well location if in city: ST JOHN, KS			R.R. or street: _____ City, state, zip code: RI, ST JOHN, KS		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 3.0 in. Completion date 3-24-76 Well depth 105 ft.		
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
5. Type and color of material			9. Casing: Material IRON Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 65 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 3/16		
			10. Screen: Manufacturer's name DOOPY Type IRON Dia. 16" Slot/gauze 1/8" Length 40 Set between 65 ft. and 105 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2-3/4		
From To			11. Static water level: _____ mo./day/yr. 11 ft. below land surface Date 3-24-76		
			12. Pumping level below land surfaces: 65 ft. after 4 hrs. pumping 1150 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1500 g.p.m.		
13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 3-25-76			14. Well head completion: Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: _____ Not installed Manufacturer's name Goulds Model number 442T HP 80 Volts _____ Length of drop pipe 80 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Water Well Ser 180 Business name R 2 Great Bend, KS License No. _____ Address _____ Signed Kelly Price Date 4-10-76 Authorized representative		
18. Elevation: _____			19. Remarks: _____		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 25 S R 14 E 0
 S 14 E 0
 S 15 E 0
 S 16 E 0
 S 17 E 0
 S 18 E 0
 S 19 E 0
 S 20 E 0
 S 21 E 0
 S 22 E 0
 S 23 E 0
 S 24 E 0
 S 25 E 0
 S 26 E 0
 S 27 E 0
 S 28 E 0
 S 29 E 0
 S 30 E 0