


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Barstow # E 1

1. Location of well:		County <i>Stafford</i>	Fraction <i>NW 1/4 SW 1/4 SW 1/4</i>	Section number <i>2</i>	Township number <i>T 25 S</i>	Range number <i>R 15 W E 1</i>
2. Distance and direction from nearest town or city: <i>2 miles South</i>		Owner of well: <i>L. D. Dilling Co.</i>		City, state, zip code: <i>Great Bend Kan</i>		
Street address of well location if in city:						
4. Locate with "X" in section below:		Sketch map:				6. Bore hole dia. <i>8</i> in. Completion date Well depth <i>80</i> ft. <i>4-28-78</i>
						7. Cable tool ☐ Rotary ☐ Driven ☐ Dug Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
5. Type and color of material		From To				8. Use: Domestic ☐ Public supply ☐ Industry Irrigation ☐ Air conditioning ☐ Stock Lawn ☐ Oil field water ☐ Other
						9. Casing: Material ☐ Height: Above or below Threaded ☐ Welded ☒ Surface <i>1 1/2</i> in. RMP ☐ PVC ☒ Weight <i>287.3</i> lb./ft. Dia. <i>5</i> in. to <i>80</i> ft. depth Wall Thickness: inches or Dia. ☐ in. to ☐ ft. depth gage No. <i>200</i>
		<i>Clay</i> 0 45				10. Screen Manufacturer's name <i>Shotcrete</i>
		<i>Sandy Clay</i> 45 60				Type <i>Band</i> Dia. <i>3</i>
		<i>Gravel</i> 60 80				Slot/gauge <i>1/4"</i> Length <i>20</i>
						Set between <i>8</i> ft. and <i>80</i> ft.
						Gravel pack? ☒ Size range of material <i>1/8 to 1/4</i>
						11. Static water level: <i>22</i> ft. below land surface Date <i>4-28-78</i>
						12. Pumping level below land surfaces: <i>22</i> ft. after <i>100</i> hrs. pumping <i>100</i> g.p.m. ft. after <i>100</i> hrs. pumping <i>100</i> g.p.m. Estimated maximum yield <i>200</i> g.p.m.
						13. Water sample submitted: <i>1/8 to 1/4</i> mo./day/yr. Yes ☐ No ☒ Date
						14. Well head completion: Pitless adapter <i>12</i> inches above grade
						15. Well grouted? ☒ With: Neat cement ☒ Bentonite ☐ Concrete ☐ Depth: From <i>0</i> ft. to <i>15</i> ft.
						16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? ☒ Yes ☐ No
						17. Pump: ☐ Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>Myself Water Well Service</i> Business name License No. Address <i>Great Bend Kan</i> Signed <i>Charles C. Myers</i> Date <i>4-28-78</i> Authorized representative