

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

STAFFORD

1. Location of well: County <u>Edwards</u> Fraction <u>NE 1/4 SE 1/4 NW 1/4</u> Section number <u>10</u> Township number <u>T 25 S</u> Range number <u>R 15 W</u>			
2. Distance and direction from nearest town or city: <u>4 S. 1/2 E. Macksville</u> Street address of well location if in city: <u>Kansas</u>		3. Owner of well: <u>Bruce Mathias</u> R.R. or street: <u></u> City, state, zip code: <u>Lewis Kansas</u>	
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 		6. Bore hole dia. <u>60</u> in. Completion date <u>8-25-78</u> Well depth <u>60</u> ft.	
5. Type and color of material		7. <u>X</u> Cable tool <u>X</u> Rotary <u></u> Driven <u></u> Dug <u></u> Hollow rod <u></u> Jetted <u></u> Bored <u></u> Reverse rotary	
Top Soil		8. Use: <u></u> Domestic <u></u> Public supply <u></u> Industry <u></u> Irrigation <u></u> Air conditioning <u>X</u> Stock <u></u> Lawn <u></u> Oil field water <u></u> Other	
BR. Clay		9. Casing: Material <u></u> Height: Above or below Threaded <u></u> Welded <u></u> Surface <u>12</u> in. RMP <u>X</u> PVC <u></u> Weight <u>200</u> lb./ft.	
Gravel		Dia. <u>5</u> in. to <u>40</u> ft. depth Wall Thickness: inches or Dia. <u></u> in. to <u></u> ft. depth gage No. <u>200</u>	
Clay		10. Screen: Manufacturer's name <u>Jessy Lowell</u> Type <u>RMP</u> Dia. <u>5</u> Slot gauge <u></u> Length <u>20</u> Set between <u>40</u> ft. and <u>60</u> ft. Gravel pack? <u>X</u> Size range of material <u>4x5</u>	
Gravel		11. Static water level: <u>18</u> ft. below land surface Date <u>8-25-78</u> mo./day/yr.	
		12. Pumping level below land surfaces: hrs. pumping <u>Not Pumped</u> g.p.m. ft. after <u>Not Pumped</u> g.p.m. Estimated maximum yield <u>20</u> g.p.m.	
		13. Water sample submitted: <u></u> mo./day/yr. Yes <u>X</u> No <u></u> Date <u></u>	
		14. Well head completion: <u>12</u> Inches above grade Pitless adapter <u></u>	
		15. Well grouted? <u></u> With: <u>X</u> Neat cement <u></u> Bentonite <u></u> Concrete <u></u> Depth: From <u>0</u> ft. to <u>10</u> ft.	
		16. Nearest source of possible contamination: ft. <u>0</u> Direction <u>East</u> Type <u></u> Well disinfected upon completion? <u>X</u> Yes <u></u> No <u></u>	
		17. Pump: <u>X</u> Not installed Manufacturer's name <u></u> Model number <u></u> HP <u></u> Volts <u></u> Length of drop pipe <u></u> ft. capacity <u></u> g.p.m. Type: <u></u> Submersible <u></u> Turbine <u></u> Jet <u></u> Reciprocating <u></u> Centrifugal <u></u> Other	
18. Elevation:		19. Remarks:	
Topography: <u></u> Hill <u></u> Slope <u>X</u> Upland <u></u> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Carl Hayse Water Well Serv. 224</u> Business name License No. <u>603 S. Maple, Greensburg, Ks.</u> Address Signed <u>Carl Hayse</u> Date <u>8-25-78</u> Authorized representative	