

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stafford	Fraction cn$\frac{1}{2}$ ne$\frac{1}{4}$ <small>1/4 1/4 1/4</small>	Section number 24	Township number 25 <small>T S R</small>	Range number 15 <small>15 16 17</small>
2. Distance and direction from nearest town or city: 6s. 2 3/4e.			3. Owner of well: Big Springs Drilling Inc. R.R. or street: Box 8287 Munger Sta. City, state, zip code: Wichita Ks, 67208			
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 7 in. Completion date 7-12-77 Well depth 45 ft.			
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material			9. Casing: Material PVC Height: Above XXXX Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP 4 PVC Weight _____ lbs./ft. Dia. 4 in. to 45 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. sch. 40			
			10. Screen: Manufacturer's name _____ MPI Type pvc Dia. 4" Slot/gauze 1/16" Length 16" Set between 29 ft. and 45 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"			
			11. Static water level: _____ mo./day/yr. 3 ft. below land surface Date 7-12-77			
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: oil test ft. 65 Direction se Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Waterwell Ser. 186 Business name _____ License No. _____ Address R. 2 Great Bend, Ks. Signed Kelly Price Date 9-10-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 25
 R 15
 E 24
 Sec 24
 1/4 C
 1/4 NE
 1/4 NE