WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

						Topeka, Kansas 66620	
1 1	County Fraction			Section number		Township number Range number	
1. Location of well:	Stafford	SW 1/4 SE1/4 SE	E 1/4 26			T X 25 S R 15 EW	
9½ miles Southeast of Macksville, KS Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:		Fred Grunder (?) St. John, KS 67576	
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 24 in. Completion date 8-1-77 Well depth 85 ft. 7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary	
- NW NE - E E E E E E E E E					8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other		
S 1						9. Casing: MaterialStee Height Above or below Threaded Welded _X isurface 12 in . RMP PVC Weight30 • 3lbs ./ft . Dial_6 in . to45ft . depth Wall Thickness: inches or	
5. Type and color of material				From	То	Dia in. to ft. depth gage No 7 ga 10. Screen: Manufacturer's name Doerr	
Top soil	& sandy clay			0	8	Two Double-slot Dia 16"	
Sand & gravel				8	34	Set between <u>45</u> ft. and <u>85</u> ft.	
Yellow clay				34	35	Gravel pack? <u>VES</u> Size range of material 3/8-200	
Sand & gravel				35	84	11. Static water level: mo./day/yr. 7 ft. below land surface Date 6-21-77	
Brown cla	у			84	85	12. Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m. 13. Water sample submitted: mo./day/yr. Yes No Date	
			_			14. Well head completion: Pitless adapter Inches above grade	
						15. Well grouted? <u>Yes</u> With: <u>X</u> Neat cement Bentonite Concrete Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: FIELD ft Direction Type Well disinfected upon completion? Yes X No.	
						17. Pump: Not installed	
						Manufacturer's name Western Land Roller Model number 14"-1 stage 75 volts Length of drop pipe 50 ft. capacity 400 p.p.m.	
						Type: Submersible X Turbine	
(Use a second sheet if needed)					-	Jet Reciprocating Other 6	
18. Elevation: 19. Remarks:					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report		
Topography: Hill Slope						is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name Address Great Bend, 16 65730	
Upland Valley						Signed Authorized representative	